The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

WATER WELL REPORT
STATE OF WASHINGTON

Start Card No. W114440
Water Right Permit No. AAS 935

(1) OWNER: Name STERN, DAVE & DARLENE Address 4312 FOXEN CT SANTA MARIA, CA 93455-

(2) LOCATION OF WELL: County ISLAND - SE 1/4 NE 1/4 Sec 31 T 30 N, R 3E WM

(2a) STREET ADDRESS OF WELL (or nearest address) PARKWOOD RD

30N3E31H

(3) PROPOSED USE: DOMESTIC

(4) TYPE OF WORK: Owner's Number of well (if more than one)
NEW WELL Method: ROTARY

(5) DIMENSIONS: Diameter of well 6 inches
Drilled 42 ft. Depth of completed well 379.7 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Dia. from +2 ft. to 376.7 ft.
WELDED Dia. from ft. to ft.
Dia. from ft. to ft.

Perforations: NO
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: YES
Manufacturer's Name COOK
Type STAINLESS STEEL Model No.
Diam. 6 slot size 15 from 374.7 ft. to 379.7 ft.
Diam. slot size from ft. to ft.

Gravel packed: NO Size of gravel
Gravel placed from ft. to ft.

Surface seal: YES To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? NO
Type of water? Depth of strata ft.
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ... ft.
Static level 317.3 ft. below top of well Date 06/03/99
Artesian Pressure lbs. per square inch Date
Artesian water controlled by

(10) WELL LOG

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

MATERIAL	FROM	TO
BROWN SILT GRAVEL & SAND	0	14
GRAY GRAVEL & SAND	14	16
GRAY SAND & GRAVEL	16	20
BROWN GRAVEL & SILT	20	22
BROWN GRAVEL SAND & SILT	22	60
GRAY SAND & GRAVEL	60	70
BROWN SAND & SILT	70	75
BROWN SILT SAND & GRAVEL	75	80
GRAY SAND & GRAVEL	80	175
GRAY SAND GRAVEL & SILT	175	183
GRAY SAND CLAY & WOOD	183	190
GRAY CLAY	190	204
GRAY GRAVEL & CLAY	204	210
GRAY SAND SILT & GRAVEL	210	216
GRAY GRAVEL SAND & SILT	216	220
GRAY SAND	220	240
GRAY SAND GRAVEL & WOOD	240	243
GRAY SAND & GRAVEL	243	264
GRAY SAND & WOOD	264	276
GRAY SILT CLAY & SAND	276	300
BROWN SAND	300	305
GRAY SAND & SILT	305	315
GRAY CLAY & SAND	315	317
GRAY SILT & SAND	317	320
GRAY CLAY & SAND	320	323
GRAY SILT & CLAY	323	326
GRAY SAND & SILT	326	335
GRAY SILT & SAND	335	348
GRAY SAND & SILT	348	354
GRAY SAND CLAY & SILT	354	360
GRAY SAND & WATER	360	369
GRAY SAND CLAY & WATER	369	370
GRAY SAND & WATER	370	

SEP 22 1999

Work started 04/28/99 Completed 05/03/99

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.
Was a pump test made? YES If yes, by whom? HAYES DRILLING
Yield: 33 gal./min with 19.65 ft. drawdown after 4.5 hrs.

Recovery data

Time	Water Level	Time	Water Level	Time	Water Level
00.01	328.6	00.02	319.4	00.03	318.2
00.04	317.8	00.05	317.5		

Date of test 06/03/99
Bailer test 2 gal/min. .5 ft. drawdown after 1.5 hrs.
Air test gal/min. w/ stem set at ft. for hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? YES

WELL CONSTRUCTOR CERTIFICATION:
I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME HAYES DRILLING, INC.
(Person, firm, or corporation) (Type or print)

ADDRESS 5696 ERSKIG RD. BOW, WA

[SIGNED] [signature] License No. 2189

Contractor's Registration No. HAYESDI106J5 Date 09/16/99