Note: Carbon paper not nec... forms are impregnated with chemical which automatically reproduces file w... on each underlying copy.

TYLOR RD. 33/2E/19J

33/02-19J

WATER WELL REPORT

STATE OF WASHINGTON

Application No. G1-21372-P

Permit No. ....

...le Original and First Copy with ... Division of Water Management
...nd Copy — Owner's Copy
...d Copy — Driller's Copy

OWNER: Name Taylor Rd Comm. assoc. Address

LOCATION OF WELL: County Island NE SE Sec. 19 T. 33 N., R. 2E W.M.

...ring and distance from section or subdivision corner 580'S & 400'W of E 1/4 cor.

PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☒ Irrigation ☐ Test Well ☐ Other ☐

17 homes

) TYPE OF WORK: Owner's number of well (if more than one) ....

New well ☒ Deepened ☐ Reconditioned ☐

Method: Dug ☐ Bored ☐ Cable ☐ Driven ☐ Rotary ☐ Jetted ☐

) DIMENSIONS: Diam... of well 6 inches.

Drilled 243 ft. Depth of ...pleted well 243 ft.

) CONSTRUCTION DETAILS

Casing installed: 6 " Diam. ... 0 ft. to 238 ft.

Threaded ☐ " Diam. ... ft. to ... ft.

Welded ☐ " Diam. ... ft. to ... ft.

Perforations: Yes ☐ No ☒

Type of perforator used

SIZE of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

Screens: Yes ☒ No ☐

Manufacturer's Name C...

Type Brass Model No.

Diam. 6" Slot size 14 ... 238 ft. to 243 ft.

Diam. Slot size ... ft. to ft.

Gravel packed: Yes ☐ No ☒ Size of gravel:

Gravel placed from ft. to ft.

Surface seal: Yes ☐ No ☒ To what depth? ft.

Material used in seal

Did any strata contain unusable water? Yes ☐ No ☐

Type of water? Depth of strata

Method of sealing strata off

(7) PUMP: Manufacturer's Name Goulds

Type: Sub HP 7 ½

(8) WATER LEVELS: Land-surface elevation above mean sea level ≈ 300 ft.

Static level 215' 3" ft. below top of well Date July 71

Artesian pressure lbs. per square inch Date

Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is measured below static water level

Was a pump test made? Yes ☒ No ☐ If yes, by whom? Bebe Pump

Yield: 40 gal./min. with 24 ft. drawdown after 8 hrs.

" " " "

" " "

Recovery data (time taken as zero when pump turned off) (measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test

Bailer test 20 gal./min. with 10½ ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
HARD PAN	4	71
GRAVEL (CONTAINED LITTLE SAND)	71	167
FINE WATER SAND	167	182
CLAY BROWN TURNING GRAY	182	224
SANDY CLAY	224	230
WATER SAND Good	230	243
WATER SAND FINER	244	

Work Started June 16, 1971 Completed July 2, 1972

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Whidbey Drillers (Person, firm, or corporation) (Type or print)

Address RT 2 Bx 494 OAK HARBOR WN

[Signed] [illegible] (Well Driller)

License No. 223 02/09/15 Date Oct 30, 1972

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

WASHINGTON STATE DEPARTMENT OF ECOLOGY

Well Tagging Form

Unique Well Tag No: AGA548 $01

RECORD VERIFICATION (check one)

- [ ] Well Report available *(please attach this form to the well report and submit it to the Ecology Regional Office near you)*
- [ ] Verification inconclusive
- [ ] Well Report not available

WELL OWNERSHIP, IF DIFFERENT FROM WELL REPORT

First Name Taylor Rd Water system Last Name

Street Address 87195

City State

LOCATION OF WELL, IF DIFFERENT FROM WELL REPORT

Well Address 383 WHISPERING PINES Rd

City County

T N R W M Sec 1/4 of the

FOR AGENCY USE ONLY

Latitude

Longitude

- [ ] GPS
- [ ] Topographic Map
- [ ] Survey
- [ ] Computer generated

Elevation at land surface feet/meters *(circle one)*

- [ ] Digital Altimeter
- [ ] Topographic Map
- [ ] Other

Additional information, if available.

- [ ] Location marked on topographic map *(please attach)*
- [ ] Location marked on air photo *(please attach)*

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

FOR AGENCY USE ONLY

WELL CHARACTERISTICS

.cal Description of well (size of casing, type of well, housing, etc.)

6" WELL CASING SURROUNDED BY CIRCULAR CEMENT STRUCTURE

PUMP HOUSE / HOLDING TANK NEARBY

NOTE. 11-26-00 / CEMENT STRUCTURE CURRENTLY BEING REPLACED DUE TO DAMAGE

ion of Well Identification Tag

CASING

supplemental tag needed for ease of identifying well? ☐ Yes ☒ No

where was tag placed? _____

C	B	A
F	G	H
L	K	J
P	Q	R

Scale 1 24,000 (1"=2,000')

Indicate the location of the well within the Section by drawing a dot at that point.

SECTION _____

ENTS

OR ECOLOGY WATER RESOURCES PROGRAM ONLY

ight # _____ Date Issued _____

One Application Permit Certificate Claim Exempt