The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

RECEIVED
NOV 15 1995
DEPT. OF ECOLOGY

ENTERED

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. A31865
Unique Well I.D. #
Water Right Permit No.

(1) OWNER: Name SCATCHET HEAD WATER DIST Address C/O 4010 STONE WAY N SEATTLE, WA 98103-

(2) LOCATION OF WELL: County ISLAND - SE 1/4 NW 1/4 Sec 15 / T 28N N. / R 3E WM
(2a) STREET ADDRESS OF WELL (or nearest address) CLINTON, CLINTON 28/3E/15-F

(3) PROPOSED USE: MUNICIPAL

(4) TYPE OF WORK: Owner's Number of well (If more than one)
ABANDONED Method: ROTARY

(5) DIMENSIONS: Diameter of well inches
Drilled ft. Depth of completed well ft.

(6) CONSTRUCTION DETAILS:
Casing installed: " Dia. from ft. to ft.
WELDED CASING " Dia. from ft. to ft.
" Dia. from ft. to ft.

Perforations: YES
Type of perforator used AIR PERFORATOR
SIZE of perforations 2 in. by 1/4 in.
3 perforations from -7 ft. to 90 ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: NO
Manufacturer's Name
Type Model No.
Diam. slot size from ft. to ft.
Diam. slot size from ft. to ft.

Gravel packed: NO Size of gravel
Gravel placed from ft. to ft.

Surface seal: NO To what depth? ft.
Material used in seal
Did any strata contain unusable water? NO
Type of water? Depth of strata ft.
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ... ft.
Static level ft. below top of well Date
Artesian Pressure lbs. per square inch Date
Artesian water controlled by

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.
Was a pump test made? NO If yes, by whom?
Yield: gal./min with ft. drawdown after hrs.

Recovery data

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test gal/min. ft. drawdown after hrs.
Air test gal/min. w/ stem set at ft. for hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? NO

(10) WELL LOG

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

MATERIAL	FROM	TO
Well was in a pit approx. 5' by 8', deep. Casing size 10" Perforated from -7' to 85'. Filled with Bentonite, 11 bags powder & 8 bags hole plug. Welded on cap then filled pit 1/2 full with cement.		

Work started 10/10/95 Completed 10/10/95

WELL CONSTRUCTOR CERTIFICATION:
I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME ARCADIA DRILLING INC.
(Person, firm, or corporation) (Type or print)

ADDRESS SE 170 WALKER PARK RD

[SIGNED] License No. 2053

Contractor's Registration No. ARCADDIO98K1 Date 11/08/95