The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

3/13/10 P

WATER WELL REPORT
STATE OF WASHINGTON

Start Card No. 207904
Water Right Permit No.

(1) OWNER: Name MABANA SHORES Address 16016 A VILLAGE GREEN DR MILL CREEK, WA 98012-

(2) LOCATION OF WELL: County SNOHOMISH - SE 1/4 SW 1/4 Sec 10 T 30 N., R 5E WM

(2a) STREET ADDRESS OF WELL (or nearest address) RED WING RD

(3) PROPOSED USE: TEST WELL

(4) TYPE OF WORK: Owner's Number of well (If more than one) 6
NEW WELL Method: ROTARY

(5) DIMENSIONS: Diameter of well 6 inches
Drilled 116 ft. Depth of completed well 111 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Dia. from +2 ft. to 100 ft.
WELDED " Dia. from ft. to ft.
" Dia. from ft. to ft.

Perforations: NO
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: YES
Manufacturer's Name JOHNSON
Type Chanel Pack Model No.
Diam. 6 slot size 10-20 from 100 ft. to 105.5 ft.
Diam. 6 slot size 20-40 from 105.5 ft. to 111 ft.

Gravel packed: NO Size of gravel
Gravel placed from ft. to ft.

Surface seal: YES To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? NO
Type of water? Depth of strata ft.
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ... ft.
Static level 86 ft. below top of well Date 01/13/93
Artesian Pressure lbs. per square inch Date
Artesian water controlled by

(10) WELL LOG

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

RECEIVED
JAN - 4 1993
DEPT. OF ECOLOGY

| MATERIAL | FROM | TO |
|---|---|---|
| TOPSOIL | 0 | 1 |
| BROWN SAND & GRAVEL | 1 | 76 |
| BROWN SAND | 76 | 90 |
| BROWN SAND BROWN CLAY & WATER | 90 | 105 |
| GRAY CLAY | 105 | 106 |
| GRAY SILT CLAY & WATER | 106 | |

Work started 12/23/92 Completed 01/13/93

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.
Was a pump test made? NO If yes, by whom?
Yield: gal./min with ft. drawdown after hrs.

Recover. data
Time Water Level Time Water Level Time Water Level

Date of test / /
Bailer test 2 gal/min. 12 ft. drawdown after 1.5 hrs.
Air test gal/min. w/ stem set at ft. for hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? NO

WELL CONSTRUCTOR CERTIFICATION:
I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME HAYES DRILLING, INC.
(Person, firm, or corporation) (Type or print)

ADDRESS 556 ERSHIG RD. BOW, WA

(SIGNED) [signature] License No. 1825

Contractor's Registration No. HAYESDI106J5 Date 01.15.93

2910

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

2L/3E/10P

**** REVISED ****

WATER WELL REPORT
STATE OF WASHINGTON

Start Card No 207893
Water Right Permit No

(1) OWNER Name MABANA SHORES Address 16016 A VILLAGE GREEN RD MILL CREEK 9801 WA 98012-

(2) LOCATION OF WELL County ISLAND - SE 1/4 SW 1/4 Sec 10 T 30 N R 3E WM
(2a) STREET ADDRESS OF WELL (or nearest address) RED WING RD

(3) PROPOSED USE MUNICIPAL

(4) TYPE OF WORK Owner's Number of well (If more than one) 5
DEEPENED Method ROTARY

(5) DIMENSIONS Diameter of well 6 inches
Drilled 115 ft Depth of completed well 111 ft

(6) CONSTRUCTION DETAILS
Casing installed 6 " Dia from +2 ft to 98 ft
WELDED Dia from ft to ft
Dia from ft to ft

Perforations NO
Type of perforator used
SIZE of perforations in by in
perforations from ft to ft
perforations from ft to ft
perforations from ft to ft

Screens YES
Manufacturer's Name HOWARD SMITH
Type STAINLESS STEEL Model No Channel pack
Diam 4 slot size 20-40 from 98 ft to 103 ft
Diam 4 slot size 10-20 from 105 ft to 110 ft

There is a 2'X 4" blank between the two screens.

Gravel packed NO Size of gravel
Gravel placed from ft to ft

Surface seal YES To what depth? 18 ft
Material used in seal BENTONITE
Did any strata contain unusable water? NO
Type of water? Depth of strata ft
Method of sealing strata off

(7) PUMP Manufacturer's Name
Type H P

(8) WATER LEVELS Land-surface elevation above mean sea level ft
Static level 87 ft below top of well Date 02/11/93
Artesian Pressure lbs per square inch Date
Artesian water controlled by

(9) WELL TESTS Drawdown is amount water level is lowered below static level
Was a pump test made? NO If yes by whom?
Yield gal /min with ft drawdown after hrs

Recovery data

| Time | Water Level | Time | Water Level | Time | Water Level |
|---|---|---|---|---|---|

Date of test / /
Bailer test 1 5 gal/min 9 ft drawdown after 1 hrs
Air test gal/min w/ stem set at ft for hrs
Artesian flow g p m Date
Temperature of water Was a chemical analysis made? NO

(10) WELL LOG

Formation Describe by color character size of material and structure and show thickness of aquifers and the kind and nature of the material in each stratum penetrated with at least one entry for each change in formation

| MATERIAL | FROM | TO |
|---|---|---|
| TOPSOIL | 0 | 1 |
| BROWN SAND & GRAVEL | 1 | 55 |
| BROWN GRAVEL & SAND | 55 | 56 |
| BROWN SAND & GRAVEL | 56 | 68 |
| BROWN SILT SAND & WATER | 68 | 98 |
| BROWN SAND CLAY & WATER | 98 | 104 |
| GRAY CLAY | 104 | 105 |
| GRAY SILT SAND & CLAY | 105 | 109 |
| GRAY SILT SAND WOOD | 109 | 113 |
| - SEEPAGE | 109 | 113 |
| GRAY CLAY | 113 | |

ORIGINAL Log has wrong sec, Find it and attach this one to it

Work started 02/10/93 Completed 02/11/93

WELL CONSTRUCTOR CERTIFICATION
I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards Materials used and the information reported above are true to my best knowledge and belief

NAME HAYES DRILLING, INC
(Person firm, or corporation) (Type or print)

ADDRESS 556 ERSHIG RD BOW, WA

[SIGNED] [signature] License No 1825

Contractor s Registration No HAYESDI106J5 Date 02/22/93

WELL SITE MEETS ALL SIGHTING CRITERIA UNDER I.C.C. 8.09 BASED ON INFORMATION SUPPLIED BY THE OWNER OR OWNER'S AUTHORIZED REPRESENTATIVE. 2909

WASHINGTON STATE DEPARTMENT OF ECOLOGY

# Well Tagging Form

**Unique Well Tag No:** AGA 1082

## RECORD VERIFICATION (check/one)

- [ ] Well Report available *(please attach this form to the well report and submit it to the Ecology Regional Office near you)*
- [ ] Verification inconclusive — See #4
- [ ] Well Report not available

## WELL OWNERSHIP, IF DIFFERENT FROM WELL REPORT

First Name MABANA 49608 Last Name

Street Address

City State

## LOCATION OF WELL, IF DIFFERENT FROM WELL REPORT

Well Address PARK @ 318 S RICE CT.

City County

T N R WM Sec 1/4 of the

## FOR AGENCY USE ONLY

Latitude

Longitude

- [ ] GPS
- [ ] Topographic Map
- [ ] Survey
- [ ] Computer generated

Elevation at land surface feet/meters *(circle one)*

- [ ] Digital Altimeter
- [ ] Topographic Map
- [ ] Other

**Additional information, if available**

- [ ] Location marked on topographic map *(please attach)*
- [ ] Location marked on air photo *(please attach)*

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

## FOR AGENCY USE ONLY

## WELL CHARACTERISTICS

ical Description of well (size of casing type of well housing etc )

Exposed 6' head Farthest from PH (Tan w/green trim)

site in mid-park at address

on of Well identification Tag

supplemental tag needed for ease of identifying well? ☐ Yes ☑ No

where was tag placed? _____

| | | |
|---|---|---|
| C | B | A |
| F | G | H |
| L | K | J |
| P | Q | R |

Scale 1 24 000 (1' =2 000')

Indicate the location of the well within the Section by drawing a dot at that point

SECTION _____

MENTS

## FOR ECOLOGY WATER RESOURCES PROGRAM ONLY

Right # _____ Date Issued _____

One Application Permit Certificate Claim Exempt