The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

Well tag id: ALQ064

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy 30/2E/34/D

WATER WELL REPORT

STATE OF WASHINGTON

Application No. 30/02-34D

Permit No.

(1) OWNER: Name JOHN ESTES Address 10522-235TH S.W. EDMONDS

(2) LOCATION OF WELL: County ISLAND — NW¼ NW¼ Sec. 34 T. 30 N., R. 2 E W.M.

Bearing and distance from section or subdivision corner 800 EAST 600 SOUTH of NW CORNER SEC 34

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one)

New well ☒ Deepened ☐ Reconditioned ☐

Method: Dug ☐ Bored ☐ Cable ☒ Driven ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.

Drilled 243 ft. Depth of completed well 234 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 230 ft.

Threaded ☐ " Diam. from ft. to ft.

Welded ☒ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒

Type of perforator used

SIZE of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

Screens: Yes ☒ No ☐

Manufacturer's Name COOK

Type 55 Model No.

Diam. 6 Slot size 10 from 230 ft. to 234 ft.

Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☒ Size of gravel:

Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 35 ft.

Material used in seal BENTONITE

Did any strata contain unusable water? Yes ☐ No ☒

Type of water? Depth of strata

Method of sealing strata off

(7) PUMP: Manufacturer's Name STA RITE

Type: SUB H.P. 1

(8) WATER LEVELS: Land-surface elevation above mean sea level 130 ft.

Static level 130 ft. below top of well Date 9-75

Artesian pressure lbs. per square inch Date

Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☒ No ☐ If yes, by whom? DRILLER

Yield: 7 gal./min. with MAX ft. drawdown after 1 hrs.

" " " "

" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test 8-30-75

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	2
GRAY HARD PAN & ROCK	2	24
" CLAY	24	160
" SAND & CLAY W.W.	160	187
BLUE CLAY	187	215
GRAY CLAY & SAND FINE W.W.	215	230
" SAND FINE W.W.	230	234
" SILT W.W.	234	24

RECEIVED
APR 0 1 2008
DEPT. OF ECOLOGY

Work started 9-1, 1975 Completed 9-20, 19

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B & W DRILLING CO (Person, firm, or corporation) (Type or print)

Address P.O. BOX 55 FREELAND WA 98

[Signed] M C Johnson (Well Driller)

License No. 265 Date 11-24, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

The Dep. The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy 30/2E/34/D

WATER WELL REPORT

STATE OF WASHINGTON

Application No. 30/02-34D

Permit No.

(1) OWNER: Name JOHN ESTES Address 10522-235th S.W. EDMONDS 98020

(2) LOCATION OF WELL: County ISLAND — NW¼ NW¼ Sec. 34 T. 30 N., R. 2 E. W.M.

Bearing and distance from section or subdivision corner 800 EAST 600 SOUTH of NW CORNER SEC 34

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one)

New well ☒ Deepened ☐ Reconditioned ☐

Method: Dug ☐ Bored ☐ Cable ☒ Driven ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.

Drilled 243 ft. Depth of completed well 234 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 230 ft.

Threaded ☐ " Diam. from ft. to ft.

Welded ☒ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒

Type of perforator used

SIZE of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

Screens: Yes ☒ No ☐

Manufacturer's Name COOK

Type SS Model No.

Diam. 6 Slot size 10 from 230 ft. to 234 ft.

Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☒ Size of gravel:

Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 35 ft.

Material used in seal BENTONITE

Did any strata contain unusable water? Yes ☐ No ☒

Type of water? Depth of strata

Method of sealing strata off

(7) PUMP: Manufacturer's Name STA RITE

Type: SUB H.P. 1

(8) WATER LEVELS: Land-surface elevation above mean sea level 130 ft.

Static level 130 ft. below top of well Date 9-75

Artesian pressure lbs. per square inch Date

Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☒ No ☐ If yes, by whom? DRILLER

Yield: 7 gal./min. with MIN ft. drawdown after 1 hrs.

" " " "

" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test 8-30-75

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
TOP SOIL	0	2
GRAY HARD PAN + ROCK	2	24
" CLAY	24	160
" SAND & CLAY W/W	160	187
BLUE CLAY	187	215
GRAY CLAY + SAND FINE W/W	215	230
" SAND FINE W/W	230	234
" SILT W/W	234	243

Work started 9-1, 1975. Completed 9-20, 1975

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B & W DRILLING CO (Person, firm, or corporation) (Type or print)

Address P.O. Box 55 FREELAND WA 98249

[Signed] M C Johnson (Well Driller)

License No. 265 Date 11-24, 1975

(USE ADDITIONAL SHEETS IF NECESSARY)

S. F. No. 7356—OS—(Rev. 4-71).