The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

Well tag id: AAF 236

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No. .....
Permit No. 61-24393

(1) OWNER: Name John Sammons Address 23525 7th Ave. S. Zenith, WA 98

(2) LOCATION OF WELL: County Island — NE ¼ NE ¼ Sec. 15 T. 30 N., R. 3 W

Bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic ☑ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) ....
New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 226 ft. Depth of completed well 226 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 226 ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☑ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☑
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☑ No ☐
Manufacturer's Name Johnson's
Type Stainless steel Model No.
Diam. 6 Slot size 20 from 221 ft. to 226 ft.
Diam. 6 Slot size 18 from 266 ft. to 221 ft.

Gravel packed: Yes ☐ No ☑ Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes ☑ No ☐ To what depth? 20 ft.
Material used in seal Bentonite and Sand
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level .... 210 ft. 211'
Static level 210 ft. below top of well Date Oct 17-83
Artesian pressure None lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☑ No ☐ If yes, by whom? Noon Kals well Drilling
Yield: 30 gal./min. with 3 ft. drawdown after 4 hrs.
" Pumped at 255' "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
9:20 AM.	210'	11:00	212' 3"	12:30	213' 1"
10:00	211'	11:30	212'-7"	1:00	213'-5"
10:30	211' 7"	12:00	213' 0"	1:30	213'-5"

Date of test Oct 25-1983
Bailer test 15 gal./min. with 0 ft. drawdown after 2 hrs.
Artesian flow None g.p.m. Date Oct 17-1983
Temperature of water 46° Was a chemical analysis made? Yes ☑ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation

MATERIAL	FROM	TO
Brown Sand	0'	18
Blue Clay	195'	20
Gray Clay and silt and water	200'	24
Gray Fine Sand	242'	26
Gray Coarse Sand and Water	265'	27

RECEIVED
APR 0 1 2008
DEPT. OF ECOLOGY

Work started Oct 3, 1983 Completed Oct 17, 19

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Noon Kals Well Drilling (Person, firm, or corporation) (Type or print)
Address Smith Rd Camano I
[Signed] Basil Hanson (Well Driller)
License No. 1011 Date Nov 22, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

The Dep. The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

20/3-15A

Application No. .....
Permit No. 61-24393P

(1) OWNER: Name John Summers Address 23525 7th Ave. S. Zenith, WA 98188

(2) LOCATION OF WELL: County Island — NE ¼ NE ¼ Sec. 15 T. 30 N., R. 3 W.M.

Bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic ☑ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) ....
New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 276 ft. Depth of completed well 276 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 276 ft.
Threaded ☐ ....." Diam. from ..... ft. to ..... ft.
Welded ☑ ....." Diam. from ..... ft. to ..... ft.

Perforations: Yes ☐ No ☑
Type of perforator used .....
SIZE of perforations ..... in. by ..... in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

Screens: Yes ☑ No ☐
Manufacturer's Name Johnson's
Type Stainless steel Model No. .....
Diam. 6 Slot size 20 from 271 ft. to 276 ft.
Diam. 6 Slot size 18 from 266 ft. to 271 ft.

Gravel packed: Yes ☐ No ☑ Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

Surface seal: Yes ☑ No ☐ To what depth? 20 ft.
Material used in seal Bentonite And Sand
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? ..... Depth of strata .....
Method of sealing strata off .....

(7) PUMP: Manufacturer's Name .....
Type: ..... H.P. .....

(8) WATER LEVELS: Land-surface elevation above mean sea level .... 250 ft. 211'
Static level 210 ft. below top of well Date Oct 17-83
Artesian pressure None lbs. per square inch Date .....
Artesian water is controlled by ..... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☑ No ☐ If yes, by whom? Noankels Well Drilling
Yield: 30 gal./min. with 3 ft. drawdown after 4 hrs.
" Pumped AT 255' "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
9:20 AM.	210'	11:00	212' 3"	12:30	213' 1"
10:00	211'	11:30	212'-7"	1:00	213'-5"
10:30	211' 7"	12:00	213' 0"	1:30	213'-5"

Date of test Oct 25-1983
Bailer test 15 gal./min. with 0 ft. drawdown after 2 hrs.
Artesian flow None g.p.m. Date Oct 17-1983
Temperature of water 46° Was a chemical analysis made? Yes ☑ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Brown Sand	0'	195'
Blue Clay	195'	200'
Gray Clay and silt and water	200'	247'
Gray Fine Sand	247'	265'
Gray Coarse Sand And Water	265'	277'

Work started Oct 3, 1983 Completed Oct 17, 1983

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Noankels Well Drilling (Person, firm, or corporation) (Type or print)

Address Smith Rd Camano Island Basil Hanson

[Signed] Basil Hanson (Well Driller)

License No. 1011 Date Nov 22, 1983

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20