Well tag id: AL 151
30/02 -36K

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy 30/2E/36/K

WATER WELL REPORT
STATE OF WASHINGTON

Application No. .....
Permit No. .....

(1) OWNER: Name BOB WEST Address FREELAND WA 98249

(2) LOCATION OF WELL: County ISLAND — NW¼ SW¼ Sec. 36 T. 30 N., R. 2E

Bearing and distance from section or subdivision corner 500' EAST 150' SOUTH OF CENTER OF SEC 36

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) .....
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 5 inches.
Drilled 390 ft. Depth of completed well 390 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 345 ft.
Threaded ☐ 5" Diam. from 0 ft. to 385 ft.
Welded ☒ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒
Type of perforator used .....
SIZE of perforations ..... in. by ..... in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

Screens: Yes ☒ No ☐
Manufacturer's Name LOOK
Type SS Model No. .....
Diam. 5 Slot size 10 from 385 ft. to 390 ft.
Diam. ..... Slot size ..... from ..... ft. to ..... ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? ..... Depth of strata .....
Method of sealing strata off .....

(7) PUMP: Manufacturer's Name STA-RITE
Type: SUB H.P. 1½

(8) WATER LEVELS: Land-surface elevation above mean sea level .... 360 ft.
Static level 360 ft. below top of well Date 1-4-85
Artesian pressure ..... lbs. per square inch Date .....
Artesian water is controlled by ..... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom? DRILLER
Yield: 12 gal./min. with 5 ft. drawdown after 8 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test .....
Bailer test ..... gal./min. with ..... ft. drawdown after ..... hrs.
Artesian flow ..... g.p.m. Date .....
Temperature of water ..... Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, show thickness of aquifers and the kind and nature of the material in e stratum penetrated, with at least one entry for each change of format*

MATERIAL	FROM	TO
TOP SOIL	0	5
GRAY HARD PAN/ROCK	5	15
" SAND MED	150	36
" MED TO PEA GRAVEL WITH WATER	360	39

RECEIVED
FEB 26 2008
DEPT. OF ECOLOGY

Work started OCT 15, 19 84. Completed JAN 30, 19

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this repo true to the best of my knowledge and belief.

NAME B & W DRILLING CO (Person, firm, or corporation) (Type or print)

Address P.O. BOX 55 FREELAND W 982

[Signed] [illegible] (Well Driller)

License No. 265 Date 1-11, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

The Dep. The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy 30/2E/36/K

WATER WELL REPORT
STATE OF WASHINGTON

30/02-36K
Application No. .....
Permit No. .....

(1) OWNER: Name BOB WEST Address FREELAND WA 98249

(2) LOCATION OF WELL: County ISLAND — NW¼ SW¼ Sec. 36 T. 30 N., R. 2 W.M.

Bearing and distance from section or subdivision corner 550' EAST 150' SOUTH OF CENTER OF SEC 36

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) .....
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 5 inches.
Drilled 390 ft. Depth of completed well 390 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 348 ft.
Threaded ☐ 6" Diam. from 0 ft. to 385 ft.
Welded ☒ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒
Type of perforator used .....
SIZE of perforations ..... in. by ..... in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

Screens: Yes ☒ No ☐
Manufacturer's Name LOOK
Type 35 Model No. .....
Diam. 5 Slot size 10 from 386 ft. to 390 ft.
Diam. ..... Slot size ..... from ..... ft. to ..... ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? ..... Depth of strata .....
Method of sealing strata off .....

(7) PUMP: Manufacturer's Name STA-RITE
Type: SUB H.P. 1½

(8) WATER LEVELS: Land-surface elevation above mean sea level .... 360 ft.
Static level 360 ft. below top of well Date 1-4-75
Artesian pressure ..... lbs. per square inch Date .....
Artesian water is controlled by ..... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom? DRILLER
Yield: 12 gal./min. with 5 ft. drawdown after 8 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test .....
Bailer test ..... gal./min. with ..... ft. drawdown after ..... hrs.
Artesian flow ..... g.p.m. Date .....
Temperature of water ..... Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
TOP SOIL	0	5
GREY HARD PAN/ROCK	5	150
" SAND MED	150	360
" MED TO FINE GRAVEL WITH WATER	360	390

Work started OCT 15, 1974. Completed JAN 30, 1975

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B & W DRILLING CO (Person, firm, or corporation) (Type or print)

Address P.O. BOX 55 FREELAND WA 98249

[Signed] [illegible] (Well Driller)

License No. 265 Date 1-14, 1975

(USE ADDITIONAL SHEETS IF NECESSARY)

S. F. No. 7356—OS—(Rev. 4-71).