Well tag id: AGA 774

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

32/1E/20/A

WATER WELL REPORT
STATE OF WASHINGTON

Application No. ....
Permit No. ....

(1) OWNER: Name Rolling Hills Glen Cairn Comm Sec Inc Address 1126 N. Sidney Rolling Hills Oak Harbor

(2) LOCATION OF WELL: County Island — NE ¼ NE ¼ Sec 0 T 32 N., R 1E

Bearing and distance from section or subdivision corner 881 FT. SOUTH & 1150 FT. WEST FROM NE CORNER SEC

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☒ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) ....
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 8 inches.
Drilled 262 ft. Depth of completed well 262 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 8" Diam. from 0 ft. to 253 ft.
Threaded ☐ ....." Diam. from .... ft. to .... ft.
Welded ☒ ....." Diam. from .... ft. to .... ft.

Perforations: Yes ☐ No ☒
Type of perforator used ....
SIZE of perforations .... in. by .... in.
.... perforations from .... ft. to .... ft.
.... perforations from .... ft. to .... ft.
.... perforations from .... ft. to .... ft.

Screens: Yes ☒ No ☐
Manufacturer's Name COOK
Type STAINLESS Model No. ....
Diam. 8 Slot size 14 from 252 ft. to 262 ft.
Diam. .... Slot size .... from .... ft. to .... ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: ....
Gravel placed from .... ft. to .... ft.

Surface seal: Yes ☒ No ☐ To what depth? 18'+ ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? .... Depth of strata ....
Method of sealing strata off ....

(7) PUMP: Manufacturer's Name ....
Type: .... H.P. ....

(8) WATER LEVELS: Land-surface elevation above mean sea level .... ft.
Static level 114' 6" ft. below top of well Date Nov 25
Artesian pressure .... lbs. per square inch Date ....
Artesian water is controlled by .... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☒ If yes, by whom? ....
Yield: .... gal./min. with .... ft. drawdown after .... hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test ....
Bailer test 30 gal./min. with 10 ft. drawdown after — hrs.
Artesian flow .... g.p.m. Date ....
Temperature of water .... Was a chemical analysis made? Yes ☐ No ☒
EST- 200 G.P.M. + - TEST TO BE MADE LATER -

(10) WELL LOG: 32/01-20

Formation: Describe by color, character, size of material and structure, show thickness of aquifers and the kind and nature of the material in stratum penetrated, with at least one entry for each change of forma

MATERIAL	FROM	T
BR CLAY	0	3
GRAVELY CLAY	35	4
GRAVEL	47	5
GRAY CLAY	50	6
GR SANDY CLAY	63	75
BR SAND	75	8
CLAY	84	9
DIRTY SAND	97	11
WATER SAND (FINE)	118	12
CLAY	126	13
SANDY CLAY	136	1
SOUPY SAND	169	17
WATER SAND - FINE -	176	1
CLAY	179	2
SOUPY WATER SAND	230	2
WATER FORMATION Good	240	2
CLAY	262	

RECEIVED
FEB 26 2008
DEPT. OF ECOLOGY

Work started Nov 5, 1974 Completed Nov 25, 19

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this repo true to the best of my knowledge and belief.

NAME WHIDBEY DRILLERS (Person, firm, or corporation) (Type or print)

Address OAK HARBOR WN

[Signed] Dennis Faber (Well Driller)

License No. 0129 Date DEC, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

The Dep. The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy 32/1E/20/A

WATER WELL REPORT
STATE OF WASHINGTON

Application No. 61-[illegible]
Permit No.

(1) OWNER: Name Rolling Hills Glen Cairn Comm Sec Inc Address 1126 N. Sidney Rolling Hills Oak Harbor, Wn.

(2) LOCATION OF WELL: County Island — NE ¼ NE ¼ Sec. 6 T. 30 N., R. 1E W.M.

Bearing and distance from section or subdivision corner 881 FT SOUTH & 1150 FT WEST FROM NE CORNER SEC 20

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☒ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) —
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 8 inches.
Drilled 262 ft. Depth of completed well 262 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 8" Diam. from 0 ft. to 253 ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☒ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☒ No ☐
Manufacturer's Name COOK
Type STAINLESS Model No.
Diam. 8 Slot size 14 from 252 ft. to 262 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☒ Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 18'+ ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ft.
Static level 114' 6" ft. below top of well Date Nov 25
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☒ If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test 30 gal./min. with 10 ft. drawdown after — hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☒
EST- 200 G.P.M. + — TEST TO BE MADE LATER —

(10) WELL LOG: 32/01-20A

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
BR CLAY	0	35
GRAVELY CLAY	35	47
GRAVEL	47	50
GRAY CLAY	50	63
GR SANDY CLAY	63	75
BR SAND	75	84
CLAY	84	97
DIRTY SAND	97	118
WATER SAND (FINE)	118	126
CLAY	126	136
SANDY CLAY	136	169
SOUPY SAND	169	176
WATER SAND -FINE-	176	179
CLAY	179	230
SOUPY WATER SAND	230	240
WATER FORMATION Good	240	262
CLAY	262	

Work started Nov 5, 1974 Completed Nov 25, 1974

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WHIDBEY DRILLERS (Person, firm, or corporation) (Type or print)

Address OAK HARBOR WN

[Signed] Dennis Foster (Well Driller)

License No. 0129 Date DEC, 1974

(USE ADDITIONAL SHEETS IF NECESSARY)

S. F. No. 7356—OS—(Rev. 4-71).

The Dep. The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

WASHINGTON STATE DEPARTMENT OF ECOLOGY

Well Tagging Form

503

Unique Well Tag No: AGA774

RECORD VERIFICATION (check/one)

- [ ] Well Report available *(please attach this form to the well report and submit it to the Ecology Regional Office near you)*
- [ ] Verification inconclusive
- [ ] Well Report not available

WELL OWNERSHIP, IF DIFFERENT FROM WELL REPORT

First Name ROLLING HILLS GLEN CAIRN Last Name

Street Address

City State

LOCATION OF WELL, IF DIFFERENT FROM WELL REPORT

Well Address BALLFIELD ON SHAWN Rd

City County

T N R WM Sec 1/4 of the

FOR AGENCY USE ONLY

Latitude

Longitude

- [ ] GPS
- [ ] Topographic Map
- [ ] Survey
- [ ] Computer generated

Elevation at land surface feet/meters *(circle one)*

- [ ] Digital Altimeter
- [ ] Topographic Map
- [ ] Other

Additional information, if available

- [ ] Location marked on topographic map *(please attach)*
- [ ] Location marked on air photo *(please attach)*

State Health

The Dep. The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

FOR AGENCY USE ONLY

WELL CHARACTERISTICS

Physical Description of well (size of casing type of well housing etc.)

8" CASING INSIDE ~~to~~ PLYWOOD SHED (~4' x 4' x 12'), PAINTED WHITE W/BLUE TRIM CYCLONE FENCE (~6')

Location of Well Identification Tag

Cory

Was supplemental tag needed for ease of identifying well? ☐ Yes ☒ No

If yes where was tag placed? _____

D	C	B	A
E	F	G	H
M	L	K	J
N	P	Q	R

Scale 1 24 000 (1 =2 000')

Indicate the location of the well within the Section by drawing a dot at that point.

SECTION _____

COMMENTS _____

FOR ECOLOGY WATER RESOURCES PROGRAM ONLY

Water Right # _____ Date Issued _____

Circle One Application Permit Certificate Claim Exempt