32/01-36F

File Original and First Copy with Department of Ecology
Second Copy — Owner
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No.
Permit No.

(1) OWNER: Name Rhodena Water Address 239 N. Rhodena Dr. Coupeville 98239

(2) LOCATION OF WELL: County ISLAND — SE ¼ NW ¼ Sec 36 T. 32 N., R. 1 E W.M.

Bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☑ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) 3

New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 187 ft. Depth of completed well 187 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 177 ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☑ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☑
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☑ No ☐
Manufacturer's Name Johnson
Type STAINLESS Model No.
Diam. 6 Slot size 12 from 177 ft. to 187 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☑ Size of gravel
Gravel placed from ft. to ft.

Surface seal: Yes ☑ No ☐ To what depth? 18+ ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: Sub H.P. 1

(8) WATER LEVELS: Land-surface elevation above mean sea level ft.
Static level 134½ ft. below top of well Date Aug 80
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☑ If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test 20 gal./min. with 18 ft. drawdown after 4 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☑

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Gravel-Sand-mix		8
Gravelly Clay	8	25
Sandy Hard	25	45
Dirty Sand	45	80
Sand	80	158
Water formation-Sand	158	170
Dirty Water Sand	170	175
Good Water Sand	175	187
fine Sand		187
50 GPM. MAX		

Work started Aug, 19 80 Completed Aug 6, 19 80

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Whidbey Well Driller (Person, firm, or corporation) (Type or print)

Address Oak Harbor Wn

[Signed] [illegible] (Well Driller)

License No. 129 Date Aug 6, 1980

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

WASHINGTON STATE DEPARTMENT OF ECOLOGY

Well Tagging Form

Unique Well Tag No: AGA9386

RECORD VERIFICATION (check ✓ one)

- [ ] Well Report available *(please attach this form to the well report and submit it to the Ecology Regional Office near you)*
- [ ] Verification inconclusive
- [ ] Well Report not available

Sec #2

WELL OWNERSHIP, IF DIFFERENT FROM WELL REPORT

First Name RHODENA BEACH W DIST Last Name

72150-R

Street Address

City State

LOCATION OF WELL, IF DIFFERENT FROM WELL REPORT

Well Address ACROSS FROM 172 RHODENA

City County

T N R WM Sec 1/4 of the

FOR AGENCY USE ONLY

Latitude

Longitude

- [ ] GPS
- [ ] Topographic Map
- [ ] Survey
- [ ] Computer generated

Elevation at land surface feet/meters *(circle one)*

- [ ] Digital Altimeter
- [ ] Topographic Map
- [ ] Other

Additional information, if available.

- [ ] Location marked on topographic map *(please attach)*
- [ ] Location marked on air photo *(please attach)*

State Health

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

FOR AGENCY USE ONLY

WELL CHARACTERISTICS

ysical Description of well (size of casing type of well housing etc)

6" CASING INSIDE TAN PANELED HOUSE WITH SIDING LID (4' x 3' x 3') ADJACENT TO PH (TAN, SIDING W/SLOPED ROOF 25 x 20' x 20') AND SRC #1

cation of Well Identification Tag

CASING

is supplemental tag needed for ease of identifying well? ☐ Yes ☒ No

s where was tag placed? _____

D	C	B	A
	F	G	H
I	L	K	J
	P	Q	R

Scale 1 24 000 (1 =2,000)

Indicate the location of the well within the Section by drawing a dot at that point

SECTION _____

MENTS

FOR ECOLOGY WATER RESOURCES PROGRAM ONLY

Right # _____ Date Issued _____

One Application Permit Certificate Claim Exempt