The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

Welltag id: ALT105

File Original and First Copy with Department of Ecology
Second Copy—Owner's Copy
Third Copy—Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. [redacted] 32/2135F

Water Right Permit No. _____

(1) OWNER: Name PETER NAJAR Address 623 W 225N CAMANO IS.

(2) LOCATION OF WELL: County ISLAND SE ¼ NW ¼ Sec. 35 T. 32 N., R. 2E W

(2a) STREET ADDDRESS OF WELL (or nearest address) SAME AS ABOVE

(3) PROPOSED USE: ☑ Domestic ☐ Irrigation ☐ DeWater Industrial ☐ Test Well ☐ Municipal ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) _____
Abandoned ☐ New well ☑ Deepened ☐ Reconditioned ☐
Method: Dug ☐ Cable ☐ Rotary ☑ Bored ☐ Driven ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 370 feet. Depth of completed well 365 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: _____ " Diam. from _____ ft. to _____ ft.
Welded ☑ 6 " Diam. from +3 ft. to 356 ft.
Liner installed ☐
Threaded ☐ _____ " Diam. from _____ ft. to _____ ft.

Perforations: Yes ☐ No ☑
Type of perforator used _____
SIZE of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

Screens: Yes ☑ No ☐
Manufacturer's Name Johnson
Type S/STEEL Model No. _____
Diam. 6 Slot size 12 from 360 ft. to 365 ft.
Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Gravel packed: Yes ☐ No ☑ Size of gravel _____
Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes ☑ No ☐ To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(7) PUMP: Manufacturer's Name UNKNOWN
Type: _____ H.P. _____

(8) WATER LEVELS: Land-surface elevation above mean sea level _____ ft.
Static level 334 ft. below top of well Date 10/29/92
Artesian pressure _____ lbs. per square inch Date _____
Artesian water is controlled by _____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☑ If yes, by whom? _____
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test _____
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Airtest 12 gal./min. with stem set at 362 ft. for 1 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes ☐ No ☑

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTIO

Formation: Describe by color, character, size of material and structure, and sh thickness of aquifers and the kind and nature of the material in each stratum penetrat with at least one entry for each change of information.

MATERIAL	FROM	TO
TOP SOIL	0	3
HARD PAN W/BOULDERS	3	12
SAND & GRAVEL	125	20
BOULDERS & COBBLES	200	23
SANDY CLAY & GRAVEL	230	30
BROWN SAND	307	33
GRAY SANDY CLAY	332	355
GRAY SAND & GRAVEL	355	36
HARD PAN W/GRAVEL	365	37

WELL SCREEN HAS 4' OF 5" DROP PIPE PLUS PACKER TOP PLUS 7' OF 5" TAIL ON BOTTOM FOR AN OVER A LENGTH OF 15' 10"

RECEIVED
NOV 18 1992
DEPT. OF ECOLOGY

RECEIVED
FEB 26 2008
DEPT. OF ECOLOGY

Work started 10/21, 19 92 Completed 10/29, 19

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this w and its compliance with all Washington well construction standa Materials used and the information reported above are true to my b knowledge and belief.

NAME WATKINS WELL DRILLING CO. (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address 556 N SUNSET DR CAMAN

(Signed) Ken Watkins (WELL DRILLER) License No. 057

Contractor's Registration No. WATKIWW134P2 Date 11/21, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

The Dep. The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

File Original and First Copy with Department of Ecology
Second Copy—Owner's Copy
Third Copy—Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. [redacted]
32/2135F

Water Right Permit No. _____

(1) OWNER: Name PETER NAJAR Address 623 W 225 N CAMANO IS. WA.

(2) LOCATION OF WELL: County ISLAND SE ¼ NW ¼ Sec. 35 T. 32 N., R. 2E W.M.

(2a) STREET ADDDRESS OF WELL (or nearest address) SAME AS ABOVE

(3) PROPOSED USE: ☑ Domestic ☐ Irrigation ☐ DeWater Industrial ☐ Test Well ☐ Municipal ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) _____
Abandoned ☐ New well ☑ Deepened ☐ Reconditioned ☐
Method: Dug ☐ Cable ☐ Rotary ☑ Bored ☐ Driven ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 370 feet. Depth of completed well 365 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: _____ " Diam. from _____ ft. to _____ ft.
Welded ☑ 6 " Diam. from +3 ft. to 356 ft.
Liner installed ☐
Threaded ☐ _____ " Diam. from _____ ft. to _____ ft.

Perforations: Yes ☐ No ☑
Type of perforator used _____
SIZE of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

Screens: Yes ☑ No ☐
Manufacturer's Name JOHNSON
Type S/STEEL Model No. _____
Diam. 6 Slot size 12 from 360 ft. to 365 ft.
Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Gravel packed: Yes ☐ No ☑ Size of gravel _____
Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes ☑ No ☐ To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(7) PUMP: Manufacturer's Name UNKNOWN
Type: _____ H.P. _____

(8) WATER LEVELS: Land-surface elevation above mean sea level _____ ft.
Static level 334 ft. below top of well Date 10/29/92
Artesian pressure _____ lbs. per square inch Date _____
Artesian water is controlled by _____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☑ If yes, by whom? _____
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test _____

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Airtest 12 gal./min. with stem set at 362 ft. for 1 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes ☐ No ☑

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
TOP SOIL	0	3
HARD PAN W/BOULDERS	3	125
SAND & GRAVEL	125	200
BOULDERS & COBBLES	200	230
SANDY CLAY & GRAVEL	230	307
BROWN SAND	307	332
GRAY SANDY CLAY	332	355
GRAY SAND & GRAVEL	355	365
HARD PAN W/GRAVEL	365	370

WELL SCREEN HAS 4' OF 5" DROP PIPE PLUS PACKER ON TOP PLUS 7' OF 5" TAIL PIPE ON BOTTOM FOR AN OVER ALL LENGTH OF 15' 10"

RECEIVED
NOV 18 1992
DEPT. OF ECOLOGY

Work started 10/21, 19 92 Completed 10/29, 19 92

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME WATKINS WELL DRILLING CO. (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address 556 N SUNSET DR CAMANO IS. WA

(Signed) Ken Watkins (WELL DRILLER) License No. 0576

Contractor's Registration No. WATKIWI3492 Date 11/2, 19 92

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20 (10/87) -1329- 3