3210N 24H

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

Application No. G1-23021
Permit No. G1-23021P

(1) OWNER: Name CHARLES L GOSSELIN Address 1160 N W Bch Rd Coupeville WA 98239

(2) LOCATION OF WELL: County ISLAND N½ SE ¼ NE ¼ Sec 24 T 32 N., R. 1 W.M.

Bearing and distance from section or subdivision corner AT INTERSECTION OF LOTS A, B, C & D SHORT PLOT # 77/49/24/

(3) PROPOSED USE: Domestic ☑ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one)....
New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 241 ft. Depth of completed well 241 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 236½ ft.
Threaded ☐ ....." Diam. from ..... ft. to ..... ft.
Welded ☐ ....." Diam. from ..... ft. to ..... ft.

Perforations: Yes ☐ No ☑
Type of perforator used .....
SIZE of perforations ..... in. by ..... in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

Screens: Yes ☑ No ☐
Manufacturer's Name JOHNSON
Type WIRE STAINLESS Model No. 304
Diam. 6 Slot size 14 from 226 ft. to 241 ft.
Diam. ..... Slot size ..... from ..... ft. to ..... ft.

Gravel packed: Yes ☐ No ☑ Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

Surface seal: Yes ☑ No ☐ To what depth? 18+ ft.
Material used in seal CLAY
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? ..... Depth of strata .....
Method of sealing strata off .....

(7) PUMP: Manufacturer's Name GOULDS
Type: SUB 25EL30412 H.P. 3

(8) WATER LEVELS: Land-surface elevation above mean sea level.... 300 ft.
Static level 210 ft. below top of well Date DEC 77
Artesian pressure ..... lbs. per square inch Date .....
Artesian water is controlled by ..... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☐ If yes, by whom? .....
Yield: ..... gal./min. with ..... ft. drawdown after ..... hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test DEC 77
Bailer test 25 gal./min. with 13- ft. drawdown after 6 hrs.
Artesian flow ..... g.p.m. Date .....
Temperature of water ..... Was a chemical analysis made? Yes ☒ No ☐

(10) WELL LOG: (900'N & 440'W) Ye ¼ [redacted] COR

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
CLAY	0	5
SANDY HARD	5	11
GRAVEL	11	25
SAND & GRAVEL	25	42
SAND & CLAY	42	67
DIRTY SAND	67	110
DRY SAND	110	176
SANDY CLAY	176	218
WATER SAND (5GPM)	218	220
SANDY CLAY	220	227
WATER IN SAND	227	241
APPROX 50 GPM		

AUG 20 1980

230'/USGS

Work started DEC 1977 Completed DEC 1977

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WHIDBEY WELL DRILLERS (Person, firm, or corporation) (Type or print)

Address OAK HARBOR WN

[Signed] Dennis Faber (Well Driller)

License No. 129 Date DEC 1977

(USE ADDITIONAL SHEETS IF NECESSARY)

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.