The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

File Original and First Copy with Department of Ecology
Second Copy—Owner's Copy
Third Copy—Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. W125577

7762 - JOB #

AFJ 868

(1) OWNER: Name MCCLELLAN, DAVID Address PO BOX 716, LANGLEY, WA 98260

(2) LOCATION OF WELL: County Island NE ¼ NW ¼ Sec. 14 T. 29 N. R. 2E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) 1780 SCENIC AVE, FREELAND, WA 29-2E-14C

(3) PROPOSED USE: ☒ Domestic ☐ Irrigation ☐ DeWater Industrial ☐ Test Well ☐ Municipal ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) 1
Abandoned ☐ New well ☒ Deepened ☐ Reconditioned ☐ Method: Dug ☐ Cable ☐ Rotary ☒ Bored ☐ Driven ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 380 feet. Depth of completed well 368 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Diam. from +2 ft. to 361 ft.
Welded ☒ " Diam. from ft. to ft.
Liner installed ☐ Threaded ☐ 8 " Diam. from +.66 ft. to 255 ft.

Perforations: Yes ☐ No ☒
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☒ No ☐
Manufacturer's Name COOK
Type STAINLESS Model No.
Diam. 6 Slot size 30 from 357 ft. to 368 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☐ Size of gravel
Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ft.
Static level 321.5 ft. below top of well Date 8/11/00
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom? HDI
Yield: 90 gal./min. with 13 ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test 2 gal./min. with .16 ft. drawdown after .5 hrs.
Airtest 20 gal./min. with stem set at 355 ft. for 1.5 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

RECEIVED AUG 31 2000 DEPARTMENT OF ECOLOGY WELL DRILLING UNIT

MATERIAL	FROM	TO
TOPSOIL	0	1
BROWN SAND & SILT	1	6
GRAY SAND & SILT & GRAVEL	6	30
BROWN SAND & SILT	30	60
BROWN SAND & SILT & GRAVEL	60	80
BROWN SILT & SAND	80	90
BROWN SAND & SILT & GRAVEL	90	113
GRAY CLAY & SILT & SAND	113	255
GRAY SAND & WATER	255	271
GRAY SAND & SILT	271	290
GRAY CLAY	290	291
GRAY SAND & SILT & CLAY	291	355
GRAY SAND & GRAVEL & WATER	355	369
GRAY SAND & CLAY	369	

Work started 07/19/00, 19. Completed 07/31/00, 19

WELL CONSTRUCTOR CERTIFICATION:
I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME HAYES DRILLING (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
Address 5696 ERSHIG ROAD, BOW WA 98232
(Signed) [signature] (WELL DRILLER) License No. 2189
Contractor's Registration No. HAYESDI106J5 Date 8/24/00, 19

(USE ADDITIONAL SHEETS IF NECESSARY) 7092-WL#

Well site meets all sighting criteria under I.C.C. 8.09 based on information supplied by the owner or owner's authorized representative.