File Original with
Department of Ecology
Second Copy - Owner's Copy
Third Copy - Driller's Copy

110642

WATER WELL REPORT

STATE OF WASHINGTON

Notice of Intent W 128648
UNIQUE WELL I D # AGR 504
Water Right Permit No — 32-2E-2B

(1) OWNER: Name STUART YOUNG Address 5500 N.E. PENRITH RD, SEATTLE

(2) LOCATION OF WELL. County ISLAND NW 1/4 NE 1/4 Sec 2 T 32 N R 2 E WM

(2a) STREET ADDRESS OF WELL: (or nearest address) STRAWBERRY PT RD, OAK HARBOR WA 98277

TAX PARCEL NO. R 23202-

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐ DeWater

(4) TYPE OF WORK. Owner's number of well (if more than one) ____
☒ New Well ☐ Deepened ☐ Reconditioned ☐ Decommission
Method: ☐ Dug ☒ Cable ☐ Rotary ☐ Bored ☐ Driven ☐ Jetted

(5) DIMENSIONS: Diameter of well 6 inches
Drilled 175 feet Depth of completed well 175 ft

(6) CONSTRUCTION DETAILS
Casing Installed:
☒ Welded 6 " Diam from 169½ ft to 175 ft
☐ Liner installed " Diam from ft to ft
☐ Threaded " Diam from ft to ft

Perforations: ☐ Yes ☒ No
Type of perforator used ____
SIZE of perforations ____ in by ____ in
____ perforations from ____ ft to ____ ft

Screens: ☒ Yes ☐ No ☒ K-Pac Location 169
Manufacturer's Name COOK
Type STAINLESS Model No ____
Diam. 6 Slot Size 10 from 170 ft to 175 ft.
Diam ____ Slot Size ____ from ____ ft to ____ ft

Gravel/Filter packed: ☐ Yes ☒ No ☐ Size of gravel/sand ____
Material placed from ____ ft to ____ ft

Surface seal: ☒ Yes ☐ No To what depth? 18+ ft
Material used in seal BENTONITE
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? ____ Depth of strata ____
Method of sealing strata off ____

(7) PUMP: Manufacturer's Name ____
Type ____ H P ____

(8) WATER LEVELS: Land-surface elevation above mean sea level 180 ft
Static level 75 ft below top of well Date 3-02
Artesian pressure ____ lbs per square inch Date ____
Artesian water is controlled by ____
(Cap, valve, etc)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom? ____
Yield ____ gal /min with ____ ft drawdown after ____ hrs
Yield ____ gal /min with ____ ft drawdown after ____ hrs
Yield ____ gal /min with ____ ft drawdown after ____ hrs
Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test ____
Bailer test 10 gal /min with 70 ft drawdown after 2 hrs
Airtest ____ gal./min with ____ ft drawdown after ____ hrs
Artesian flow ____ g p m Date ____
Temperature of water ____ Was a chemical analysis made? ☐ Yes ☒ No

(10) WELL LOG or DECOMMISSIONING PROCEDURE DESCRIPTION
Formation Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information Indicate all water encountered

MATERIAL	FROM	TO
HARD PAN	0	16
CLAY	16	36
SANDY HARD	36	55
GRAVEL	55	80
DIRTY SAND	80	93
SANDY CLAY	93	141
SOUPY FINE SAND	141	157
CLAY	157	164
FINE WATER SAND	164	175
CLAY	175	

RECEIVED
MAR 25 2002
DEPT OF ECOLOGY

Work Started FEB 2002 Completed MAR 2, 02

WELL CONSTRUCTION CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards Materials used and the information reported above are true to my best knowledge and belief

Type or Print Name G. BOONSTRA License No 038
(Licensed Driller/Engineer)
Trainee Name — License No —
Drilling Company WHIDBEY DRILLERS
(Signed) ____ License No ____
(Licensed Driller/Engineer)
Address OAK HARBOR WA 98277
Contractor's Registration No WHIDZ89 MM Date MAR. 02

(USE ADDITIONAL SHEETS IF NECESSARY)

Ecology is an Equal Opportunity and Affirmative Action employer For special accommodation needs, contact the Water Resources Program at (360) 407-6600 The TDD number is (360) 407-6006

ECY 050-1-20 (11/98)

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.