The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

Well tag id: AGA664

STATE OF WASHINGTON
DEPARTMENT OF CONSERVATION
AND DEVELOPMENT

WELL LOG No. App. 6049

Date 9-20, 1961

Record by well driller

Source driller's record

Location: State of WASHINGTON

County Island

Area

Map

SW ¼ NE ¼ sec. 19 T. 30 N., R. 2 E.

Diagram of Section

Drilling Co. Island Well Drilling Co.

Address Freeland, Wash.

Method of Drilling Date, 1953

Owner Lagoon Point Water Co.

Address 410 Green Bldg., Seattle

Land surface, datum ft. above/below

30/2.19

File number

Correlation	Material	Thickness (feet)	Depth (feet)
	Hardpan with rocks	54	54
	Sand cement & hardpan	51	105
	Sand & gravel w/b	11	116
	PUMP TEST:		
	Dim. 6"x116'		
	SWL: 93'		
	DD: 10'		
	Yield: 30 g.p.m.		
	Type & size of pump: 5 h.p. Piston		
	Type & size of motor: electric		
	CASING:		
	6" diam. from 0 to 105'		
	Shoe - 6 7/8" O.D. welded casing		
	PERFORATIONS:		
	Cook red brass wire wound screens		
	#1-20 & #1-14 slot from 105 to 116'		

(Transcribe driller's terminology literally but paraphrase as necessary, in parentheses. If material water-bearing, so state and record static level if reported. Give depths in feet below land-surface datum unless otherwise indicated. Correlate with stratigraphic column, if feasible. Following log of materials, list all casings, perforations, screens, etc.)

Turn up

Sheet ... of ... sheets

partment of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

STATE OF WASHINGTON
DEPARTMENT OF CONSERVATION
AND DEVELOPMENT

WELL LOG No. App. 6049

Date 9-20, 1961

Record by well driller

Source driller's record

Location: State of WASHINGTON

County Island

Area

Map

SW ¼ NE ¼ sec. 19 T. 30 N., R. 2 E.

Diagram of Section

Drilling Co. Island Well Drilling Co.

Address Freeland, Wash.

Method of Drilling Date, 1953

Owner Lagoon Point Water Co.

Address 410 Green Bldg., Seattle

Land surface, datum ft. above/below

CORRELATION	MATERIAL	THICKNESS (feet)	DEPTH (feet)
	(Transcribe driller's terminology literally but paraphrase as necessary, in parentheses. If material water-bearing, so state and record static level if reported. Give depths in feet below land-surface datum unless otherwise indicated. Correlate with stratigraphic column, if feasible. Following log of materials, list all casings, perforations, screens, etc.)		
	Hardpan with rocks	54	54
	Sand cement & hardpan	51	105
	Sand & gravel w/b	11	116
	PUMP TEST:		
	Dim. 6"x116'		
	SWL: 93'		
	DD: 10'		
	Yield: 30 g.p.m.		
	Type & size of pump: 5 h.p. Piston		
	Type & size of motor: electric		
	CASING:		
	6" diam. from 0 to 105'		
	Shoe - 6/7/8" O.D. welded casing		
	PERFORATIONS:		
	Cook red brass wire wound screens		
	#1-20 & #1-14 slot from 105 to 116'		

Turn up Sheet ... of ... sheets

30/2-19G
File number