The Dep. The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

OK (271)

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy 29/3E/17/M

WATER WELL REPORT
STATE OF WASHINGTON

Application No. 29103-17 M
Permit No

(1) OWNER Name VERIANE GABELEIN Address BOX 950 CLINTON, WASH 98236

(2) LOCATION OF WELL County ISLAND - THE S½ OF THE NE¼ NW¼ SW¼ Sec 17 T 29 N R 3E WM

Bearing and distance from section or subdivision corner 1320 No. & 1320 EAST OF THE S.W. CORNER OF SECT. 17

(3) PROPOSED USE Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK Owner's number of well (if more than one)
New well ☒ Method Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS Diameter of well 6 inches
Drilled 150 ft Depth of completed well 149 ft

(6) CONSTRUCTION DETAILS

Casing installed
Threaded ☐ Diam from ft to ft
Welded ☒ 6 Diam from +1 ft to 143 ft

Perforations Yes ☐ No ☒
Type of perforator used
SIZE of perforations in by in
perforations from ft to ft
perforations from ft to ft
perforations from ft to ft

Screens Yes ☒ No ☐
Manufacturer's Name JOHNSON
Type SS-WRBE Model No 6x5x25
Diam 6 Slot size 25 from 143 ft to 149 ft
Diam Slot size from ft to ft

Gravel packed Yes ☐ No ☒ Size of gravel
Gravel placed from ft to ft

Surface seal Yes ☒ No ☐ To what depth? 18 ft
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP Manufacturer's Name Goulds
Type 13 EM 10412 H.P 1

(8) WATER LEVELS Land-surface elevation above mean sea level 105 ft
Static level 113 ft below top of well Date 6-15-74
Artesian pressure — lbs per square inch Date —
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes by whom? 0058
Yield 22 gal/min with 3 ft drawdown after 4 hrs

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
1430	113'				
1830	116'				
1831	113'				

Date of test 6-15-74
Bailer test 45 gal/min with 2 ft drawdown after 4 hrs
Artesian flow — g.p.m. Date —
Temperature of water 47 Was a chemical analysis made? Yes ☒ No ☐

(10) WELL LOG

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
HARD PAN - ROCKS TO 4" DIA	0'	5'
PIT RUN GRAVEL & SAND	5'	39'
MED. SAND - BROWN - NON	39'	49'
PEA GRAVEL - ROCKS TO 2"	49'	68'
COARSE SAND - BROWN - NON	68'	89'
BLUE CLAY	89'	90'
FINE SAND - GRAY - NON	90'	112'
MED. SAND - BLUE - BEAR	112'	113'
COARSE SAND - BLUE - BEARING	113'	149'
BLUE CLAY - PULL BACK	149'	150'

Work started MAY 25 1974 Completed JUNE 14 1974

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME SOUTH ISLAND WELL CONSTRUCTORS (Person, firm, or corporation) (Type or print)

Address 2918 E BECKER Rd. CLINTON WASH 9823

[Signed] William J. Bunton (Well Driller)

License No 0058 Date JUNE 21, 1974

(USE ADDITIONAL SHEETS IF NECESSARY)

S.I. No. 7306—OS—(Rev. 1-71)

WASHINGTON STATE DEPARTMENT OF ECOLOGY

Well Tagging Form

Unique Well Tag No: AGA 742 / 049306/01

RECORD VERIFICATION (check one)

- [ ] Well Report available *(please attach this form to the well report and submit it to the Ecology Regional Office near you)*
- [ ] Verification inconclusive
- [x] Well Report not available

WELL OWNERSHIP, IF DIFFERENT FROM WELL REPORT

First Name BAYSHORE TERRACE W SYJ Last Name

Street Address

City State

LOCATION OF WELL, IF DIFFERENT FROM WELL REPORT

Well Address ~~[illegible]~~ Same

City County

T N R W M Sec 1/4 of the

FOR AGENCY USE ONLY

Latitude

Longitude

- [ ] GPS
- [ ] Topographic Map
- [ ] Survey
- [ ] Computer generated

Elevation at land surface feet/meters *(circle one)*

- [ ] Digital Altimeter
- [ ] Topographic Map
- [ ] Other

Additional information, if available

- [ ] Location marked on topographic map *(please attach)*
- [ ] Location marked on air photo *(please attach)*

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

The Dep The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

FOR AGENCY USE ONLY

WELL CHARACTERISTICS

sical Description of well (size of casing, type of well, housing, etc.)

" CASING INSIDE CINDERBLOCK HOUSE (TAN W/ BROWN TRIM).
20'x20'x15') ADJ TO OCTAGONAL CONCRETE RES SITE DOWN
GRAVEL
DRIVEWAY BETWEEN 1030 & 1050 BAYSHORE RD

tion of Well Identification Tag

Casy

supplemental tag needed for ease of identifying well? ☐ Yes ☒ No

where was tag placed?

C	B	A
F	G	H
L	K	J
P	Q	R

Scale 1 24,000 (1"=2,000')

Indicate the location of the well within the Section by drawing a dot at that point

SECTION

MENTS

FOR ECOLOGY WATER RESOURCES PROGRAM ONLY

Right # Date Issued

One Application Permit Certificate Claim Exempt

Well tag id: AGA854

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy 29/3E/17/M

WATER WELL REPORT
STATE OF WASHINGTON

Application No. 29/03-17 A
Permit No.

(1) OWNER: Name VERLANE GABELEIN Address BOX 950 CLINTON, WASH. 98236

(2) LOCATION OF WELL: County ISLAND — THE S½ OF THE NE¼ NW¼ SW¼ Sec. 17 T. 29 N., R. 3E W.

Bearing and distance from section or subdivision corner 1320 NO. & 1320 EAST OF THE S.W. CORNER OF SECT. 17

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one)
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 150 ft. Depth of completed well 149 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: ..." Diam. from ... ft. to ... ft.
Threaded ☐ ..." Diam. from ... ft. to ... ft.
Welded ☒ 6" Diam. from +1 ft. to 143 ft.

Perforations: Yes ☐ No ☒
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☒ No ☐
Manufacturer's Name JOHNSON
Type SS-WRBE Model No. 6x5x25
Diam. 6 Slot size 25 from 143 ft. to 149 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☒ Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name Goulds
Type: 13 EM 10412 H.P. 1

(8) WATER LEVELS: Land-surface elevation above mean sea level 105 ft.
Static level 113 ft. below top of well Date 6-15-74
Artesian pressure — lbs. per square inch Date —
Artesian water is controlled by — (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom? 0058
Yield: 22 gal./min. with 3 ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
1430	113'				
1830	116'				
1831	113'				

Date of test 6-15-74
Bailer test 45 gal./min. with 2 ft. drawdown after 4 hrs.
Artesian flow — g.p.m. Date —
Temperature of water 47 Was a chemical analysis made? Yes ☒ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
HARD PAN - ROCKS TO 4" DIA	0'	5
PIT RUN GRAVEL & SAND	5'	3
MED. SAND - BROWN - NON	39'	4
PEA GRAVEL - ROCKS TO 2"	49'	6
COARSE SAND - BROWN - NON	68'	8
BLUE CLAY	89'	9
FINE SAND - GRAY - NON	90'	11
MED. SAND - BLUE - BEAR	112'	11
COARSE SAND - BLUE - BEARING	113'	14
BLUE CLAY - PULL BACK	149'	1

Work started MAY 25, 1974 Completed JUNE 14, 19

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME SOUTH ISLAND WELL CONSTRUCTORS (Person, firm, or corporation) (Type or print)

Address 2918 E. BECKER RD. CLINTON, WASH. 9

[Signed] William L. Benton (Well Driller)

License No. 0058 Date JUNE 21, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.