File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

Application No
Permit No

(1) OWNER: Name ED BRIDGES Address 1307 W. SWANTOWN, OAK HARBOR

(2) LOCATION OF WELL. County ISLAND NE ¼ SW ¼ Sec 24 T 33 N R 1 E WM

Bearing and distance from section or subdivision corner 1420'E & 160'S FM E ¼ Corner, SEC 24

(3) PROPOSED USE: Domestic ☑ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK Owner's number of well (if more than one) 1

New well ☑ Method Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches
Drilled 61 ft Depth of completed well 61 ft

(6) CONSTRUCTION DETAILS

Casing installed 6" Diam from 0 ft to 56 ft
Threaded ☐ " Diam from ft to ft
Welded ☑ Diam from ft to ft

Perforations Yes ☐ No ☑
Type of perforator used
SIZE of perforations in by in
perforations from ft to ft
perforations from ft to ft
perforations from ft to ft

Screens Yes ☑ No ☐
Manufacturer's Name JOHNSON
Type WELDED SS Model No
Diam 6 Slot size 10 from 56 ft to 61 ft
Diam Slot size from ft to ft

Gravel packed Yes ☐ No ☑ Size of gravel
Gravel placed from ft to ft

Surface seal Yes ☑ No ☐ To what depth? 18 ft
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP Manufacturer's Name
Type SUB H.P.

(8) WATER LEVELS Land-surface elevation above mean sea level 60+ ft
Static level 36 ft below top of well Date
Artesian pressure lbs per square inch Date
Artesian water is controlled by (Cap valve etc)

(9) WELL TESTS Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☑ If yes by whom?
Yield gal/min with ft drawdown after hrs

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test 20 gal/min with MAX ft drawdown after 4 hrs
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☑

(10) WELL LOG

Formation *Describe by color, character, size of material and structure and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
GRAVELY HARD PAN	0	27
SAND	27	38
WATER SAND	38	61

20 GPM.

Work started SEPT 19 Completed SEPT 19 83

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief

NAME WHIDBEY WELL DRILLING (Person firm or corporation) (Type or print)
Address OAK HARBOR
[Signed] Clarence Fobe (Well Driller)
License No 129 Date Oct 22, 19 83

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1 20

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

Well Tagging Form

WASHINGTON STATE DEPARTMENT OF ECOLOGY

S01

Unique Well Tag No: AGA 527

RECORD VERIFICATION (check ✓ one)

- [✓] Well Report available *(please attach this form to the well report and submit it to the Ecology Regional Office near you)*
- [ ] Verification inconclusive
- [ ] Well Report not available

WELL OWNERSHIP, IF DIFFERENT FROM WELL REPORT

First Name MIDGET MARKET 21665-1 Last Name

Street Address

City State

LOCATION OF WELL, IF DIFFERENT FROM WELL REPORT

Well Address

City Shine County

T N R WM Sec 1/4 of the

FOR AGENCY USE ONLY

Latitude W 122° 37 800 " [✓] GPS

Longitude N 48° 19 893 " [ ] Topographic Map

[ ] Survey

[ ] Computer generated

Elevation at land surface feet/meters *(circle one)*

[ ] Digital Altimeter

[ ] Topographic Map

[ ] Other

Additional information, if available:

[ ] Location marked on topographic map *(please attach)*

[ ] Location marked on air photo *(please attach)*

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

FOR AGENCY USE ONLY

WELL CHARACTERISTICS

Physical Description of well (size of casing type of well housing, etc.)

6" WELL CASING, TNC, HOUSED IN ROUND CONCRETE STRUCTURE THAT IS 24" THICK SAMPLING PORT PRODUCED NO WATER, SO INSIDE SAMPLE WAS TAKEN FROM SNIC INSIDE STORE

Location of Well identification Tag

ON WELL CASING

Was supplemental tag needed for ease of identifying well? ☐ Yes ☑ No

If yes where was tag placed?

D	C	B	A
E	F	G	H
M	L	K	J
N	P	Q	R

Scale 1 24,000 (1"=2,000')

Indicate the location of the well within the Section by drawing a dot at that point.

SECTION 24 L

COMMENTS

FOR ECOLOGY WATER RESOURCES PROGRAM ONLY

Water Right # _____ Date Issued _____

Circle One Application Permit Certificate Claim Exempt