32-3E-18R

WATER WELL REPORT

Original & 1st copy - Ecology, 2nd copy - owner, 3rd copy - driller

Construction/Decommission *("x" in circle)* 159517

● Construction

○ Decommission *ORIGINAL CONSTRUCTION Notice of Intent Number* _____

CURRENT Notice of Intent No. W104186

Unique Ecology Well ID Tag No. AGK781

Water Right Permit No. _____

Property Owner Name SOUNDVIEW WATER ASSOC.

Well Street Address 1297 N. OLSEN Rd.

City CAMANO ISLAND County: ISLAND

Location SE 1/4- 1/4 SE 1/4 Sec 18 Twn 32 R 3 (WWM circle one or WWM)

Lat/Long: (s,t,r still REQUIRED) Lat Deg _____ Lat Min/Sec _____ Long Deg _____ Long Min/Sec _____

Tax Parcel No. _____

PROPOSED USE: ■ Domestic ☐ Industrial ☐ Municipal ☐ DeWater ☐ Irrigation ☐ Test Well ☐ Other _____

TYPE OF WORK: Owner's number of well (if more than one) _____

■ New Well ☐ Reconditioned *Method:* ☐ Dug ☐ Bored ☐ Driven ☐ Deepened ☐ Cable ■ Rotary ☐ Jetted

DIMENSIONS: Diameter of well 6 inches, drilled 175 ft.

Depth of completed well 171 ft.

CONSTRUCTION DETAILS

Casing Installed: ■ Welded 6" Diam. from +2 ft. to 166 ft.

☐ Liner installed _____" Diam. from _____ ft. to _____ ft.

☐ Threaded _____" Diam. from _____ ft. to _____ ft.

Perforations: ☐ Yes ■ No

Type of perforator used _____

SIZE of perfs _____ in. by _____ in. and no. of perfs _____ from _____ ft. to _____ ft.

Screens: ■ Yes ☐ No ☐ K-Pac Location _____

Manufacturer's Name NAGAOKA

Type STAINLESS STEEL Model No. _____

Diam. 5 5/8 Slot Size 12 from 166 ft. to 171 ft.

Diam. _____ Slot Size _____ from _____ ft. to _____ ft.

Gravel/Filter packed: ☐ Yes ■ No ☐ Size of gravel/sand _____

Materials placed from _____ ft. to _____ ft.

Surface Seal: ■ Yes ☐ No To what depth? 18 ft

Materials used in seal BENTONITE

Did any strata contain unusable water? ☐ Yes ■ No

Type of water? _____ Depth of strata _____

Method of sealing strata off _____

PUMP: Manufacturer's Name GOULD

Type: SUBMERSIBLE H.P. 1 HP

WATER LEVELS: Land-surface elevation above mean sea level _____ ft.

Static level 105 ft. below top of well Date 10-2-04

Artesian pressure _____ lbs. per square inch Date _____

Artesian water is controlled by _____ (cap, valve, etc.)

WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made? ☒ Yes ☐ No If yes, by whom? _____

Yield: 10 gal./min. with 57 ft. drawdown after 1 HR hrs.

Yield: 10 gal./min. with " ft. drawdown after 4 HRS hrs.

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
6 PM	57	6:33 PM	105		

Date of test _____

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.

Airtest _____ gal./min. with stem set at _____ ft. for _____ hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water _____ Was a chemical analysis made? ☒ Yes ☐ No

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information. Indicate all water encountered. (USE ADDITIONAL SHEETS IF NECESSARY.)

MATERIAL	FROM	TO
TAN SAND GRAVEL CLAY	0	12
GREY HARDPAN	12	58
SAND & GRAVEL	58	66
GREY HARDPAN	66	76
GREY SANDY CLAY	76	81
GREY HARDPAN	81	96
SAND GRAVEL CLAY	96	116
SAND	116	118
FINE SAND W/WATER	118	140
SAND, CLAY WATER	140	150
GREY CLAY	150	167
SAND W/WATER	167	175

RECEIVED

NOV 0 1 2004

DEPT OF ECOLOGY

Start Date 9-29-04 Completed Date 10-2-04

WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

■ Driller ☐ Engineer ☐ Trainee Name (Print) JOSEPH NUNES

Driller/Engineer/Trainee Signature Joseph Nunes

Driller or Trainee License No. 0611

Drilling Company CAMANO WELL DRILLING

Address PO BOX 432

City, State, Zip STANWOOD WA 98292

Contractor's Registration No. CAMANW014RZ Date 10-18-04

If trainee, licensed driller's Signature and License no. _____

Ecology is an Equal Opportunity Employer. ECY 050-1-20 (Rev 4/01)

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.