31-5E-18J

WATER WELL REPORT

Original & 1st copy - Ecology, 2nd copy - owner, 3rd copy - driller

Construction/Decommission *("x" in circle)* 186618

(x) Construction

( ) Decommission *ORIGINAL CONSTRUCTION Notice of Intent Number*

CURRENT Notice of Intent No. W238151

Unique Ecology Well ID Tag No. ALQ246

Water Right Permit No.

Property Owner Name Renee + Sean WALSTAD

Well Street Address off - Race Rd + SR 525

City Coupeville County: Island

Location NE 1/4- 1/4 SE 1/4 Sec 18 Twn 31 R 2 (EWM) or WWM *circle one*

Lat/Long: (s,t,r still REQUIRED) Lat Deg ____ Lat Min/Sec ____ Long Deg ____ Long Min/Sec ____

Tax Parcel No. R23118-106-2370

PROPOSED USE: [x] Domestic [ ] Industrial [ ] Municipal [ ] DeWater [ ] Irrigation [ ] Test Well [ ] Other

TYPE OF WORK: Owner's number of well (if more than one)

[x] New Well [ ] Reconditioned *Method:* [ ] Dug [ ] Bored [ ] Driven [ ] Deepened [ ] Cable [x] Rotary [ ] Jetted

DIMENSIONS: Diameter of well 6 inches, drilled 345 ft.

Depth of completed well 345 ft.

CONSTRUCTION DETAILS

Casing Installed: [x] Welded 6" Diam. from +18" ft. to 335 ft.

[ ] Liner installed " Diam. from ft. to ft.

[ ] Threaded " Diam. from ft. to ft.

Perforations: [ ] Yes [x] No

Type of perforator used

SIZE of perfs in. by in. and no. of perfs from ft. to ft.

Screens: [x] Yes [ ] No [x] K-Pac Location 335'

Manufacturer's Name Johnson

Type S.S. Model No. 304

Diam. 6" Slot Size 16 from 335 ft. to 340 ft.

Diam. 6 Slot Size 18 from 341 ft. to 345 ft.

Gravel/Filter packed: [ ] Yes [x] No Size of gravel/sand

Materials placed from ft. to ft.

Surface Seal: [x] Yes [ ] No To what depth? 18+ ft

Materials used in seal Bentonite

Did any strata contain unusable water? [ ] Yes [x] No

Type of water? Depth of strata

Method of sealing strata off

PUMP: Manufacturer's Name Grundfos

Type: Sub- H.P. 5 H.

WATER LEVELS: Land-surface elevation above mean sea level 340 ft.

Static level 298 ft. below top of well Date 11/22/05

Artesian pressure lbs. per square inch Date

Artesian water is controlled by (cap,valve, etc.)

WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made? [x] Yes [ ] No If yes, by whom? Driller

Yield: 40 gal./min. with 9 ft. drawdown after 1 hrs.

Yield: gal./min. with ft. drawdown after hrs.

Yield: gal./min. with ft. drawdown after hrs.

Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test

Bailer test 15 gal./min. with 1 ft. drawdown after 2+ hrs.

Airtest gal./min. with stem set at ft. for hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? [x] Yes [ ] No

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information. Indicate all water encountered. (USE ADDITIONAL SHEETS IF NECESSARY.)

MATERIAL	FROM	TO
Grey Cemenity Sand/Gravel	0	64
Grey + Brown Clay	64	141
Brown Sand + Gravel	141	165
" Hard PAN + Gravel	165	321
Water Sand + sm gravel	321	345

RECEIVED
DEC 16 2005
DEPT OF ECOLOGY

Start Date 11/15/05 Completed Date 11/22/05

WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

[x] Driller [ ] Engineer [ ] Trainee Name (Print) Jack/Ryan Harris

Driller/Engineer/Trainee Signature

Driller or Trainee License No. #1364

If trainee, licensed driller's Signature and License no.

Drilling Company Well Done Drillers

Address 440 Hill Valley Dr.

City, State, Zip Coupeville, WA 98239

Contractor's Registration No. WELLDDSNB Date 12/1/05

Ecology is an Equal Opportunity Employer. ECY 050-1-20 (Rev 4/01)

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.