The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

Well tag id: APH010

B+W DRILLING Co.

WATER WELL REPORT

STATE OF WASHINGTON

ile Original and First Copy with
epartment of Ecology
econd Copy — Owner's Copy
hird Copy — Driller's Copy

Application No. .....

Permit No. .....

(1) OWNER: Name DAVID FINN Address 4285 E. LANDS END RD. Clinton

(2) LOCATION OF WELL: County Island — SW ¼ SE ¼ Sec 14 T. 28 N., R. 3E W.M.

Bearing and distance from section or subdivision corner —

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) ....

New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☐ Driven ☐
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6" inches.
Drilled 173' ft. Depth of completed well 172 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 172' ft.
Threaded ☐ ..." Diam. from ... ft. to ... ft.
Welded ☒ ..." Diam. from ... ft. to ... ft.

Perforations: Yes ☐ No ☒
Type of perforator used ....
SIZE of perforations ... in. by ... in.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.

Screens: Yes ☒ No ☐
Manufacturer's Name COOK
Type STAINLESS STEEL Model No. ....
Diam. 6 Slot size — from 162 ft. to 172' ft.
Diam. ... Slot size ... from ... ft. to ... ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: ....
Gravel placed from ... ft. to ... ft.

Surface seal: Yes ☒ No ☐ To what depth? 20' ft.
Material used in seal Bentonite
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? .... Depth of strata ....
Method of sealing strata off ....

(7) PUMP: Manufacturer's Name STA-RITE
Type: Submersible H.P. 1

(8) WATER LEVELS: Land-surface elevation above mean sea level .... 250' ft.
Static level ... ft. below top of well Date ....
Artesian pressure ... lbs. per square inch Date ....
Artesian water is controlled by ....
(Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☒ If yes, by whom? ....
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test ....
Bailer test ... gal./min. with ... ft. drawdown after ... hrs.
Artesian flow ... g.p.m. Date ....
Temperature of water ... Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
TOPSOIL	0	1
HARD PAN Gray	1	18
HARD PAN BROWN	18	90
HARD PAN Gray	90	160
Sand Med W.W	160	173

RECEIVED
MAR 14 2008
DEPT. OF ECOLOGY

Work started August 20, 1981 Completed Sept 1, 1981

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B+W Well Drilling
(Person, firm, or corporation) (Type or print)

Address P.O. Box 55, Freeland, Wa 98249

[Signed] Joe [illegible]
(Well Driller)

License No. 264 Date Sept 10, 1981

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

BF6

R32814-050-3050

B+W DRILLING Co.

WATER WELL REPORT

STATE OF WASHINGTON

...le Original and First Copy with
...epartment of Ecology
...econd Copy — Owner's Copy
...hird Copy — Driller's Copy

Application No. .....

Permit No. .....

(1) OWNER: Name DAVID FINN Address 4235 E. LANDS END RD. Clinton

(2) LOCATION OF WELL: County Island — SW ¼ SE ¼ Sec 14 T 28 N., R 3E W.M.

Bearing and distance from section or subdivision corner —

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) ....

New well ☒ Deepened ☐ Reconditioned ☐

Method: Dug ☐ Bored ☐ Cable ☐ Driven ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6" inches.

Drilled 173' ft. Depth of completed well 172' ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 172' ft.

Threaded ☐ ..." Diam. from ... ft. to ... ft.

Welded ☒ ..." Diam. from ... ft. to ... ft.

Perforations: Yes ☐ No ☒

Type of perforator used ...

SIZE of perforations ... in. by ... in.

... perforations from ... ft. to ... ft.

... perforations from ... ft. to ... ft.

... perforations from ... ft. to ... ft.

Screens: Yes ☒ No ☐

Manufacturer's Name COOK

Type STAINLESS STEEL Model No. ...

Diam. 6 Slot size — from 162' ft. to 172' ft.

Diam. ... Slot size ... from ... ft. to ... ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: ...

Gravel placed from ... ft. to ... ft.

Surface seal: Yes ☒ No ☐ To what depth? 20' ft.

Material used in seal Bentonite

Did any strata contain unusable water? Yes ☐ No ☒

Type of water? ... Depth of strata ...

Method of sealing strata off ...

(7) PUMP: Manufacturer's Name STA-RITE

Type: Submersible H.P. 1

(8) WATER LEVELS: Land-surface elevation above mean sea level .... 250' ft.

Static level ... ft. below top of well Date ...

Artesian pressure ... lbs. per square inch Date ...

Artesian water is controlled by ... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☒ If yes, by whom? ...

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test ...

Bailer test ... gal./min. with ... ft. drawdown after ... hrs.

Artesian flow ... g.p.m. Date ...

Temperature of water ... Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
TOPSOIL	0	1
HARD PAN Gray	1	18
HARD PAN BROWN	18	90
HARD PAN Gray	90	160
Sand Med W.W	160	173

RECEIVED
MAR 14 2008
DEPT. OF ECOLOGY

Work started August 20, 1981 Completed Sept 1, 1981

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B+W Well Drilling (Person, firm, or corporation) (Type or print)

Address P.O. Box 55, Freeland, Wa 98249

[Signed] [illegible] (Well Driller)

License No. 264 Date Sept 10, 1981