The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

RECEIVED Welltag id: AGA685

NOV 0 2 1990

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

Application No. .....
Permit No. .....

(1) OWNER: Name MABANA SHORES ASSO (SL. CTY. HEALTH DEP.) Address CAMANO ISLAND

(2) LOCATION OF WELL: County ISLAND — SE ¼ SW ¼ Sec. 10 T. 30 N., R. 3

Bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☑ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) .....
New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well ..... inches.
Drilled ..... ft. Depth of completed well ..... ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 157 ft.
Threaded ☐ ....." Diam. from ..... ft. to ..... ft.
Welded ☑ ....." Diam. from ..... ft. to ..... ft.

Perforations: Yes ☐ No ☑
Type of perforator used .....
SIZE of perforations ..... in. by ..... in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

Screens: Yes ☑ No ☐
Manufacturer's Name Johnson
Type Wire Model No. 304
Diam. 6 Slot size 8 from 157 ft. to 162 ft.
Diam. ..... Slot size ..... from ..... ft. to ..... ft.

Gravel packed: Yes ☐ No ☑ Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

Surface seal: Yes ☑ No ☐ To what depth? 20 ft.
Material used in seal Bentonite & Clay
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? ..... Depth of strata .....
Method of sealing strata off .....

(7) PUMP: Manufacturer's Name Flint & Walling
Type: Sub H.P. 1

(8) WATER LEVELS: Land-surface elevation above mean sea level 110 ft.
Static level 19 ft. below top of well Date 5/27/90
Artesian pressure ..... lbs. per square inch Date .....
Artesian water is controlled by ..... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☑ No ☐ If yes, by whom? Driller
Yield: 5 gal./min. with 6 ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
[illegible]	11				
[illegible]	110				

Date of test 5/27/90
Water test ..... gal./min. with ..... ft. drawdown after ..... hrs.
Artesian flow ..... g.p.m. Date .....
Temperature of water 50 Was a chemical analysis made? Yes ☐ No ☑

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, show thickness of aquifers and the kind and nature of the material in stratum penetrated, with at least one entry for each change of formation

MATERIAL	FROM	TO
Clayey Sand 0 100	0	110
fine sand 100 115	100	115
Silt 115 125	115	125
blue clay	125	150
fine sand	150	160

NEW DRILLED WELL WELL #2

RECEIVED
APR 0 1 2008
DEPT. OF ECOLOGY

Work started 5/11, 1950 Completed 5/27, 1950

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report true to the best of my knowledge and belief.

NAME Kruckel Well Drilling (Person, firm, or corporation) (Type or print)

Address 742 N Smith Rd Camano Is Wa 98292

[Signed] [illegible] (Well Driller)

License No. 9647 Date 5/10, 1980

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20