The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

Well tag id: AGA523 29/03-17K

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

Application No. .....
Permit No. G1-2320

(1) OWNER: Name Reactor Gordon Address 2140 192ND Ave. S.E. Issaquah W

(2) LOCATION OF WELL: County Island ¼ NW¼ Sec. 17 T. 29 N., R. 3 W

Bearing and distance from section or subdivision corner 500' S and 30' E SE¼ of center Sec. 17

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) ....
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 254 ft. Depth of completed well 254 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 244 ft.
Threaded ☐ ____" Diam. from ____ ft. to ____ ft.
Welded ☒ ____" Diam. from ____ ft. to ____ ft.

Perforations: Yes ☐ No ☒
Type of perforator used ____
SIZE of perforations ____ in. by ____ in.
____ perforations from ____ ft. to ____ ft.
____ perforations from ____ ft. to ____ ft.
____ perforations from ____ ft. to ____ ft.

Screens: Yes ☒ No ☐
Manufacturer's Name Cook
Type Stainless Steel Model No. ____
Diam. 6 Slot size 10 from 244 ft. to 254 ft.
Diam. ____ Slot size ____ from ____ ft. to ____ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: ____
Gravel placed from ____ ft. to ____ ft.

Surface seal: Yes ☒ No ☐ To what depth? 45 ft.
Material used in seal Bentonite
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? ____ Depth of strata ____
Method of sealing strata off ____

(7) PUMP: Manufacturer's Name ____
Type: ____ H.P. ____

(8) WATER LEVELS: Land-surface elevation above mean sea level .... 260 ft.
Static level 222 ft. below top of well Date ____
Artesian pressure ____ lbs. per square inch Date ____
Artesian water is controlled by ____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom? Driller
Yield: 15 gal./min. with 1 ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test ____
Bailer test ____ gal./min. with ____ ft. drawdown after ____ hrs.
Artesian flow ____ g.p.m. Date ____
Temperature of water ____ Was a chemical analysis made? Yes ☒ No ☐

(10) WELL LOG: NW¼, SE¼ Sec 17

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Clay & Sand Br	0	11
H.P.	11	42
Hard Packed Sand Br.	42	68
F Sand Blue	68	83
Clay Blue	83	115
F Sand Blue	115	123
Clay Blue	123	126
F Sand Blue	126	162
C Sand Blue	162	176
F Sand " "	176	220
C Sand WW	220	223
Clay Br.	223	235
C Sand WW	235	254

RECEIVED
APR 01 2008
DEPT. OF ECOLOGY

RECEIVED
JUN 29 1979
DEPT. OF ECOLOGY

Work started 4/6, 1979 Completed 4/22, 19

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B&W Drilling Co. (Person, firm, or corporation) (Type or print)

Address P.O. Box 55 Freeland Wh.

[Signed] James Mitta & Lehman (Well Driller)

License No. 263 Date 3/28, 19