The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

341540

WATER WELL REPORT

Original & 1st copy – Ecology, 2nd copy – owner, 3rd copy – driller

DEPARTMENT OF ECOLOGY State of Washington

Construction/Decommission *("x" in circle)*

☒ Construction

☐ Decommission *ORIGINAL INSTALLATION*

Notice of Intent Number _____

PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐ DeWater ☐ Irrigation ☐ Test Well ☐ Other_____

TYPE OF WORK: Owner's number of well (if more than one) _____

☐ New well ☐ Reconditioned *Method:* ☐ Dug ☐ Bored ☐ Driven ☐ Deepened ☒ Cable ☐ Rotary ☐ Jetted

DIMENSIONS: Diameter of well 6 inches, drilled 161 ft. Depth of completed well 161 ft.

CONSTRUCTION DETAILS

Casing Installed: ☒ Welded 6" Diam. from +1.5 ft. to 143 ft.

☐ Liner installed _____" Diam. from _____ ft. to _____ ft.

☐ Threaded _____" Diam. From _____ ft. to _____ ft.

Perforations: ☐ Yes ☒ No

Type of perforator used _____

SIZE of perfs _____ in. by _____ in. and no. of perfs _____ from _____ ft. to _____ ft.

Screens: ☒ Yes ☐ No ☐ K-Pac Location 142

Manufacturer's Name JOHNSON

Type stainless Model No. TELE

Diam. 5 Slot size 15 from 142 ft. to 147 ft.

Diam. 5 Slot size 12 from 150 ft. to 161 ft.

Gravel/Filter packed: ☐ Yes ☒ No Size of gravel/sand _____

Materials placed from _____ ft. to _____ ft.

Surface Seal: ☒ Yes ☐ No To what depth? 18 ft.

Material used in seal BENTONITE

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? _____ Depth of strata _____

Method of sealing strata off _____

PUMP: Manufacturer's Name _____

Type: _____ H.P. _____

WATER LEVELS: Land-surface elevation above mean sea level ft.

Static level 124 ft. below top of well Date 4/20/2009

Artesian pressure _____ lbs. per square inch Date _____

Artesian water is controlled by _____ (cap, valve, etc.)

WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom? _____

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test _____

Bailer test 10 gal./min. with 8 ft. drawdown after 2.5 hrs.

Airtest _____ gal./min. with stem set at _____ ft. for _____ hrs.

Artesian flow _____ g.p.m. Date _____

Temperature of water _____ Was a chemical analysis made? ☐ Yes ☒ No

CURRENT

Notice of Intent No. W 257543

Unique Ecology Well ID Tag No .BAE 431

Water Right Permit No. _____

Property Owner Name THE BRIDGE CHRITIAN FELLOWSHIP

Well Street Address W TROXELL Rd

City Oak-Harbor County Island

Location NW 1/4 NE 1/4 Sec 2 Twn 33 R 1 EWM ☒ Or WWM ☐

(s, t, r Still REQUIRED)

Lat/Long Lat Deg _____ Lat Min/Sec _____

Long Deg _____ Long Min/Sec _____

Tax Parcel No. (Required) R 13302-331-3620

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information. (USE ADDITIONAL SHEETS IF NECESSARY.)

MATERIAL	FROM	TO
BROWN CLAY	0	8
GRAVELY CLAY	8	17
SILTY SAND &GRAVEL	17	30
SAND	30	79
SILTY SAND	79	92
SANDY CLAY	92	116
GRAVELY HARDPAN	116	142
SILTY GRAVEL	142	146
HARDPAN	146	150
SILTY GRAVEL	150	153
HARDPAN	153	155
SIILTY GRAVEL	155	166
SILTY CLAY	161	
WELL SITE MEETS ALL SETBACKS		
UNDER .I.C.C 8.09 BASED ON		
INFORMATION FROM OWNER		
OVERALL LENGT OF WELLSCREEN=19FT		

RECEIVED MAY 21 2009 Dept of Ecology WR-NWRO

Start Date 4/15/2009 Completed Date 4/20/2009

WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

☒ Driller ☐ Engineer ☐ Trainee Name (Print) Gerlof Boonstra

Driller/Engineer/Trainee Signature Gerlof Boonstra

Driller or trainee License No. 0038

IF TRAINEE: Driller's License No:

Driller's Signature:

Drilling Company WHIDBEY WELL DRILLERS

Address 716 Holbrook Rd

City, State, Zip Coupeville , WA, 98239

Contractor's Registration No. WHIDBWD927RW Date 4/21/2009