The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

Application No. .....
Permit No. .....

(1) OWNER: Name Cross Wood's Development Address Oak Harbor WA

(2) LOCATION OF WELL: County Island — NW ¼ SW ¼ Sec. 3 T. 32 N., R. 1 E. W.M.
Bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☑ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) 1
New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled ..... ft. Depth of completed well 174 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 158 ft.
Threaded ☐ ..." Diam. from ..... ft. to ..... ft.
Welded ☐ ..." Diam. from ..... ft. to ..... ft.

Perforations: Yes ☐ No ☑
Type of perforator used .....
SIZE of perforations ..... in. by ..... in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

Screens: Yes ☑ No ☐
Manufacturer's Name Johnson
Type Brass Model No. .....
Diam. 6 Slot size 14 from 156 ft. to 174 ft.
Diam. ..... Slot size ..... from ..... ft. to ..... ft.

Gravel packed: Yes ☐ No ☑ Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

Surface seal: Yes ☑ No ☐ To what depth? 10' ft.
Material used in seal Concrete
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? ..... Depth of strata .....
Method of sealing strata off .....

(7) PUMP: Manufacturer's Name .....
Type: ..... H.P. .....

(8) WATER LEVELS: Land-surface elevation above mean sea level ..... ft.
Static level 113' 3" ft. below top of well Date 26 mar 73
Artesian pressure ..... lbs. per square inch Date .....
Artesian water is controlled by ..... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☑ No ☐ If yes, by whom? Whidbey Drill
Yield: 60 gal./min. with 19' 3" ft. drawdown after 1 hrs.
" 60+ " 19' 3" " 2 "
" 60+ " 19' 3"+ " 4 "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
2 min	115'	30 min	113'	60 min	112' 5"
5 min	114'	40 min	112' 9"	2 hr	112' 3"
10 min	113' 6"	50 min	112' 1"	STATIC in 2 hr	

Date of test 23 March 73
Bailer test ..... gal./min. with ..... ft. drawdown after ..... hrs.
Artesian flow ..... g.p.m. Date .....
Temperature of water ..... Was a chemical analysis made? Yes ☑ No ☐

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation*

MATERIAL	FROM	TO
Gravel	0	4
Sand — dry + brown	4	49
Clay Gray	49	54
Sand + Gravel mix	54	71
Sandy Clay	71	91
Dirty Sand	91	114
Water Sand 96' SL	114	121
Sandy Clay	121	137
Water Sand (Good)	137	174
Water Sand (Finer)	174	?
Well Yields 60+ gpm @	131'6	
Well Yields 100+ gpm @	150'-	

Work started 3-12, 1973. Completed 3-26, 1973

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Whidbey Drillers (Person, firm, or corporation) (Type or print)
Address 1143 W Ft Nugent Rd
[Signed] Dennis Faber (Well Driller)
License No. 223-02-10915 Date 27 mar, 1973

(USE ADDITIONAL SHEETS IF NECESSARY)

S. F. No. 7356—OS—(Rev. 5-69)—5-69.