Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No. ....

Permit No. ....

(1) OWNER: Name CROSSWOODS WATER CO. Address 4086 400 W OAK HARBOR

(2) LOCATION OF WELL: County ISLAND — NW ¼ SW ¼ Sec. 3 T. 32 N., R. 1E W.M.

Bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☑ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one).... 2

New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 178 ft. Depth of completed well 178 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 163 ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☐ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☑
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☑ No ☐
Manufacturer's Name JOHNSON
Type STAINLESS WIRE Model No. 304
Diam. 6 Slot size 12 from 163 ft. to 168 ft.
Diam. 6 Slot size 14 from 168 ft. to 173 ft.
6 10 173 178

Gravel packed: Yes ☐ No ☑ Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes ☑ No ☐ To what depth? 18+ ft.
Material used in seal CEMENT
Did any strata contain unusable water? Yes ☐ No ☐
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: Sub HP 3

(8) WATER LEVELS: Land-surface elevation above mean sea level.... ft.
Static level 117 6 ft. below top of well Date SEPT 77
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☑ No ☐ If yes, by whom? BOBS PUMPS
Yield: 55 gal./min. with 4 ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test 50 gal./min. with ft. drawdown after 4 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
SANDY CLAY	0	25
BROWN SANDY DRY	25	52
TAN SANDY CLAY	52	65
GRAY SAND	65	75
GRAY SANDY CLAY	75	121
WATER SAND (FINE)	121	128
SANDY CLAY	128	146
WATER SAND CLEAN	146	173
CLAY CHUNKS	173	174
FINE WATER SAND	174	178+
STILL IN FINE SAND	178	
50+ GPM PUMP TEST TO BE MADE LATER		

Work started SEPT 19 77 Completed SEPT 19 77

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME (Person, firm, or corporation) (Type or print)

Address

[Signed] (Well Driller)

License No. 129 Date SEPT 19 77

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.