The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

449750

R 33033-062-2810

WATER WELL REPORT
STATE OF WASHINGTON

Start Card No. W184916
Unique Well I.D.# AHH368
Water Right Permit No.

(1) OWNER: JOE & ARRON FIRCHAU — ADDRESS: POST OFFICE BOX 0589, Snohomish 98291-0589

(2) LOCATION OF WELL: County: ISLAND — SW 1/4 SE 1/4 Sec 33 T 30 N, R 03E WM
(2a) STREET ADDRESS OF WELL (or nearest Address): 5002 SARATOGA ROAD LANGLEY WA 98260

(3) PROPOSED USE: X Domestic, Irrigation, DeWater, Industrial, TEST WELL, Municipal, Other....

(4) TYPE OF WORK: Owner/ No of Well if more than one: 1
Abandoned — New Well..... X — METHOD Dug... Bored. Deepened..... Cable. Driven Reconditioned — Rotary X

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled [illegible] Feet [illegible] of completed well [illegible] Ft.

(6) CONSTRUCTION DETAILS:
Casing Installed: Diam From Ft To Ft
Welded X 6 Diam From -1.5 Ft To 18.5 Ft
Liner Inst X 4 Diam From 9 Ft To 229 Ft
Threaded

Perforations: NO
Types of perforator used
Size of perforations Inches, by Inches
Perforations from ft to
Perforations from ft to
Perforations from ft to

Screens: YES
Manufacturer's Name: WESTERN WELL SCREEN
Type: PVC Model No.
Diam 4 Slot size 15 From 229 Ft To 249 Ft
Diam 4 Slot size From Ft To Ft

Gravel packed: YES Size of gravel: #60
Gravel placed from: 200 Ft To: 260 Ft

Surface seal: YES To What Depth?: 18.5Ft
Material used in seal BENTONITE
Did any strata contain unusable water?: NO
Type of water: Depth of strata: Ft
Method of sealing strata off:

PUMP: [illegible]er's Name: GOULDS ?
Type: [illegible] H.P. 3/4

(8) WATER LEVELS? Above mean sea level 225
Static Level 216.5 Ft. below top of well Date: 07/07/05
Artesian pressure Lbs. per square inch Date: / /
Artesian water is controlled by:

(9) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made?: YES If yes, by whom?: HIMEBAUGH DRILL
Yield: 7.7 Gal/min. with 1.3 Ft drawdown after 7.1 Hrs.
Yield: Gal/min. with Ft drawdown after Hrs.
Yield: Gal/min. with Ft drawdown after Hrs.
RECOVERY DATA

Time	Water Level	Time	Water Level	Time	Water Level
0 SEC	216.6	1 MIN	215.4	10	215.4
10 SEC	215.8	2	215.4	15	215.4
20 SEC	215.4	3	215.4		

Date of test / /
Bailer Test 7.5 gal/min with 2 ft. drawdown after 1 Hrs
Airtest gal/min with stem set at ft for Hrs
Artesian flow G.P.M. Date /
Temperature of Water Was a chemical analysis made?: YES

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION:

Formation: Describe by color, character, size of material and show thickness of aquifiers and the kind of nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
TOP SOIL	0	[illegible]
TILL, BROWN SANDY	02	75
CLAY, SILTY, BLUISH	75	115
CLAY, BLUE	115	120
SILT	120	130
FINE SAND	130	160
SILT	160	209
SAND	209	214
WOOD	214	215
SAND FINE CLAYEY	215	220
SAND MEDIUM	220	227
SAND COARSE	227	249
CLAY	249	260

THIS WELL CONFORMS TO ICC 809.07 C, D, & E AS LISTED WITH ICHD.

RECEIVED
DEPARTMENT OF ECOLOGY
MAY 09 2012
WATER RESOURCES PROGRAM
NWRO

Work Started 07/07/05 Work Completed 07/14/05

WELL CONSTRUCTOR CERTIFICATION:
I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to the best knowledge and belief.

Name: HIMEBAUGH DRILLING - BOYD HIMEBAUGH
Address: ~~528 B PORTAGE STREET~~ PO BOX 245, ARLINGTON, WA 98223
(Signed) Boyd Himebaugh License No 1877
Contractors Registration No. HIMEBD099CK Date 07/24/05