The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

N 32905-164-4300

File Original and First Copy with Department of Ecology
Second Copy—Owner's Copy
Third Copy—Driller's Copy

452240

WATER WELL REPORT

STATE OF WASHINGTON ALQ 383

Start Card No. [illegible]

Water Right Permit No. _____

(1) OWNER: Name [illegible] Address [illegible]

(2) LOCATION OF WELL: County Island ___ ¼ ___ ¼ Sec. 8 T. 29 N., R. 2 W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) _____

(3) PROPOSED USE: ☒ Domestic ☐ Irrigation ☐ Geo-Water ☐ Industrial ☐ Test Well ☐ Municipal ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) _____
Abandoned ☐ New well ☒ Deepened ☐ Reconditioned ☐
Method: Dug ☐ Cable ☒ Rotary ☐ Bored ☐ Driven ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled _____ feet. Depth of completed well _____ ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6" Diam. from +1 ft. to 145 ft.
Welded ☐ _____" Diam. from _____ ft. to _____ ft.
Liner installed ☐ _____" Diam. from _____ ft. to _____ ft.
Threaded ☐

Perforations: Yes ☐ No ☐
Type of perforator used _____
SIZE of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

Screens: Yes ☒ No ☐
Manufacturer's Name Johnson
Type Cleanlock Model No. _____
Diam. 5 Slot size 8 from 145 ft. to 150 ft.
Diam. 5 Slot size 10 from 150 ft. to 155 ft.

Gravel packed: Yes ☐ No ☒ Size of gravel _____
Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes ☒ No ☐ To what depth? 20 ft.
Material used in seal Bentonite
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(7) PUMP: Manufacturer's Name _____
Type: _____ H.P. _____

(8) WATER LEVELS: Land-surface elevation above mean sea level 200 ft.
Static level 191 ft. below top of well Date _____
Artesian pressure _____ lbs. per square inch Date _____
Artesian water is controlled by _____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☐ If yes, by whom? _____
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test _____
Bailer test 7 gal./min. with 10 ft. drawdown after 4 hrs.
Airtest _____ gal./min. with stem set at _____ ft. for _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
Topsoil	0	1
Sand Gravel - sand Clay	1	22
Sand Gravel	22	122
Fine Sand WB	122	135

RECEIVED
JAN 07 1994
ISL. CTY. HEALTH DEPT.

RECEIVED
DEPARTMENT OF ECOLOGY
MAY 23 2012
WATER RESOURCES PROGRAM
NWRO

Work started 8-5 19__ Completed 8-23 19__

WELL CONSTRUCTOR CERTIFICATION:
I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME Johnson Well Drilling (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
Address PO Box 162 Lopez WA 98261
(Signed) [signature] (WELL DRILLER) License No. 153
Contractor's Registration No. [illegible] Date 9-1 19__

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-97 (10/87) -1359-