The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

R23018-440-3400

4WU

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

AcQ055

WATER WELL REPORT
STATE OF WASHINGTON

Application No. .....
Permit No. .....

(1) OWNER: Name JOHN SCHWAGER Address 7745 N.E. SUNRISE Vista Seattle 98115

(2) LOCATION OF WELL: County ISLAND — SW ¼ SE ¼ Sec. 7 T. 30 N., R. 2 E. W.M.

Bearing and distance from section or subdivision corner [redacted] 6.7 miles south of sec 6 and 2.9 miles west of sec 8.

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☑

(4) TYPE OF WORK: Owner's number of well (if more than one) ....
New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☐ Driven ☐
Reconditioned ☐ Rotary ☑ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 260 ft. Depth of completed well 260 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 250 ft.
Threaded ☐ ..... " Diam. from ..... ft. to ..... ft.
Welded ☑ ..... " Diam. from ..... ft. to ..... ft.

Perforations: Yes ☐ No ☑
Type of perforator used .....
SIZE of perforations ..... in. by ..... in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

Screens: Yes ☑ No ☐
Manufacturer's Name JOHNSON
Type CONTINUOUS WELD S.S. Model No. .....
Diam. 5" Slot size 12 from 249 ft. to 260 ft.
Diam. ..... Slot size ..... from ..... ft. to ..... ft.

Gravel packed: Yes ☐ No ☑ Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

Surface seal: Yes ☑ No ☐ To what depth? 20 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? ..... Depth of strata .....
Method of sealing strata off .....

(7) PUMP: Manufacturer's Name STA-RITE
Type: Submersible H.P. 2

(8) WATER LEVELS: Land-surface elevation above mean sea level .... 210 ft.
Static level 211'-10" ft. below top of well Date 8/13/84
Artesian pressure ..... lbs. per square inch Date .....
Artesian water is controlled by ..... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☑ No ☐ If yes, by whom? C & W Pump Co
Yield: 25 gal./min. with 14 ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test 8/13/84
Bailer test ..... gal./min. with ..... ft. drawdown after ..... hrs.
Artesian flow ..... g.p.m. Date .....
Temperature of water ..... Was a chemical analysis made? Yes ☑ No ☐

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
TOP SOIL.	0	2
BROWN COMPACT SANDY SILT.	2	11
GRAY SANDY SILT AND GRAVEL.	11	102
GRAY SILT AND SANDY GRAVEL.	102	131
BROWN SILT AND SANDY GRAVEL.	131	157
BROWN SILTY CLAY.	157	169
GRAY FINE SAND.	169	181
BROWN SILT.	181	192
BROWN SILTY CLAY.	192	216
GRAY CLAY.	216	238
GRAY SILTY FINE SAND.	238	243
FINE TO CORASE SAND WITH GRAVEL.	243	260

RECEIVED
DEPARTMENT OF ECOLOGY
MAR 23 2012
WATER RESOURCES PROGRAM
NWRO

Work started July 20, 1984 Completed July 25, 1984

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME BYW DRILLING (Person, firm, or corporation) (Type or print)

Address 4057 E DRICK RD

[Signed] [signature] (Well Driller)

License No. 264 Date July 28, 1984

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20